



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

243
7
आफ़ादीक
अमृत महोत्सव

No. F6/DFS/MS/BNQT/NDZ/2026/337

Dated: 10/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Lado Rani (A Unit of Rajni LC Hospitality Private Limited) is running on Ground floor only located at Property no. 44, Hasanpur, Shahdara, New Delhi, building comprised of Basement + Ground + 03 upper floors, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/NDZ/BNQT/2023/52 dated 30.11.2023. The Banquet Hall was re-inspected by officer concerned of this department on 02/04/2026 in presence of Mr. Lalit Chauhan (Owner of the Banquet Hall) and found that the said Banquet Hall has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. The premises/building is fit for occupancy of Group D "Assembly Building" (Banquet Hall at Ground floor only) with effect from 10/04/2026 and valid upto 31.03.2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 10/04/2026 at New Delhi by

10/4/26
(Dr S. K. Tomar)

Dy. Chief Fire Officer (NDZ)

Reference: etl.mcdonline application no. 2026031602989.

o/c 10/4/26

Copy to:-

2. The Licensee, M/s Lado Rani (A Unit of Rajni LC Hospitality Private Limited) located at Property no. 44, Hasanpur, Shahdara, New Delhi.

Conditions for the validity of Fire Safety Certificate

12. This Fire Safety Certificate is valid for Banquet Hall at Ground floor only.
13. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
14. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
15. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
16. The trained fire fighting staff should be available round the clock.
17. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
18. Basement shall be used as NBC/UBBL 2016.
19. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
20. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
21. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
22. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1.	Name and address of the building:	M/s Lado Rani (A Unit of Rajni LC Hospitality Private Limited) located at Property no. 44, Ground floor, Hasanpur, Shahdara, New Delhi.			
2.	Building is comprised of	Basement + Ground + 03 upper floors (Banquet Hall operational at Ground floor only)			
3.	Type of occupancy	Group D - Assembly (Banquet Hall)			
4.	Type of case:	Renewal			
5.	Details of previous FSC:	F6/DFS/MS/NDZ/BNQT/2023/52 dated 30.11.2023			
6.	Fire safety directives no.:	UBBL-2016 & NBC Part-IV- 2016			
7.	Date of inspection:	02/04/2026			
8.	Name of the inspecting officer:	Rajesh Kumar Shukla, ADO (L.N)			
9.	Name and designation of the officer from the building side:	Mr. Lalit Chauhan (Owner of the Banquet Hall)			
10.	Year of construction:	2007			
11.	Reference letter no.:	etl.mcdonline application no. 2026031602989			
S.No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements (As per 35 (6))	Provide at site	Remarks MR/NMR	
1	Access to Building:				
	A	Road width	6.0 m	6.0 m	MR
	B	Gate width	NA	NA	NA
	C	Width of internal roads	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits:				
	A	No. of Staircase:			
		a) Upper floor	NA	NA	NA
		b) Basements	NA	NA	NA
	B	Width of the Staircase			
		a) Upper floors	NA	NA	NA
		b) Basements	NA	NA	NA
	C	Protection of Exits			
		a) Fire check door	Required	Provided	MR
		b) pressurization	NA	NA	NA
	D	No. of continuous staircase to terrace	1 no.	1 no.	MR
	E	Width of the corridor	NA	NA	NA
	F	Door size	2.0 m & 1.50 m	2.0 m & 1.93 m	MR
3	Compartmentation:				
	A	Fire check doors	Required	Provided	MR
	B	Sealing of horizontal & vertical opening	NA	NA	NA
	C	Fire rating of shaft doors	NA	NA	NA
	D	Water curtain	NA	NA	NA
	E	Fire dampers	NA	NA	NA
4	Smoke Management System:				
	A	Basements	NA	NA	NA
	B	Ground floor	NA	NA	NA
5	Fire Extinguishers:				
	A	Total numbers	06 nos.	10 nos.	MR
	B	Types	ABC +CO ₂	ABC +CO ₂	MR
	C	ISI marking	ISI marked	ISI marked	MR

De

6	First Aid Hose Reel:				
	A	Total no. at each floor	01 no.	1 nos.	MR
	B	Length of hose reel	30 m	30 m	MR
	C	Nozzle diameter	5 mm	5 mm	MR
7	Automatic Fire Detection and Alarm System (ADAS):				
	A	Type of detectors	NA	Provided	NA
	B	Location of main panel	NA	Provided	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate power source	NA	NA	NA
	E	Hooter's location	NA	Provided	NA
8	MOEFA:		Required	Provided	MR
9	Public Address System:		NA	NA	NA
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Ground floor	NA	NA	NA
	C	Sprinklers above false ceiling	NA	NA	NA
11	Internal Hydrants:				
	A	Size of down comer	100 mm	100 mm	MR
	B	No. of hydrants per floor	01 nos.	01 nos.	MR
	C	Hose box	01 nos.	01 nos.	MR
12	Yard Hydrants:				
	A	Total no. of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping arrangements:				
	A	Ground Level			
		a) Discharge & head of main pump	NA	NA	NA
		b) Number of main pump	NA	NA	NA
		c) Discharge & head of jockey pump	NA	NA	NA
		d) Discharge & head of standby pump	NA	NA	NA
		e) Auto starting/ manual stopping	NA	NA	NA
	B	Terrace Level			
		a) Discharge of terrace pump	900 LPM	2 x 900 LPM	MR
		b) Head of terrace pump	40 m	40 m	MR
		c) Alternate power supply	Required	Provided	MR
		d) Auto starting of pump	Auto	Provided	MR
14	Captive Water Storage for Fire Fighting:				
	A	Underground tank capacity	NA	NA	NA
	B	Draw off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	E	Access to tank	NA	NA	NA
	D	Overhead tank capacity	25,000 Ltrs	25,000 Ltrs	MR
			Required	Provided	MR
15	Exit Signage:				
16	Provision of lift:				
	A	Pressurization of lift shaft	NA	NA	NA
	B	Pressurization of lift lobby	NA	NA	NA
	C	Communication in lift car	NA	NA	NA
	D	Fireman switch	NA	NA	NA
	E	Lift signage	NA	NA	NA
			Required	Provided	MR
17	Standby Power Supply:				
18	Refuge Area:				
	A	location	NA	NA	NA
	B	Total area	NA	NA	NA
19	Fire Control Room:				
	A	Fire detection system panel	NA	NA	NA
	B	Flow switch panel	NA	NA	NA
	C	P a system panel	NA	NA	NA
	D	Battery backup	NA	NA	NA
	E	Building floor plan	NA	NA	NA

M/s Lado Rani (A Unit of Rajni LC Hospitality Private Limited) located at Property no. 44, Ground floor, Hasanpur, Shahdara, New Delhi.

20	Special Fire Protection for special risk if any	
A	Special Fire Protection system for Protection of Special Risk, if any:	NA

LEGENDS:- Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Not Provided (NP) Provide but Not Functional (PNF).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

The shortcomings issued to the Banquet Hall by this department vide letter no. F6/DFS/MS/BNQT/NDZ/2026/132 dated 13/02/2026 has been rectified by the management.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F6/DFS/MS/NDZ/BNQT/2023/52 dated 30.11.2023 is recommended to be renewed under Rule 37 of the Delhi Fire Service Rules 2010. The last date of disposal of this application is 17.04.2026.

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (L.N)

DO (East)

[Handwritten signatures and dates]
Principal Director
By. CFO to Sd/-
By. CFO (NDZ)
FI is put up, as approved
Dy. CFO (NDZ)
ms
Uploaded
10/4/26