

C-41

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/2025/ 674

Dated 21.8.2025

To,
The Principal,
Lady Irwin Sr. Secondary School,
Srimant, Madhav Rao Scindia Marg,
New Delhi.

Sub: Regarding renewal of FSC in r/o Lady Irwin Sr. Secondary School at Srimant Madhav Rao Scindia Marg, New Delhi.

Sir,

This has reference to letter no. nil dated 25.06.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 04/08/2025 in the presence of Mr. Davinder, MTS and observed that shortcomings issued earlier vide letter no. F6/DFS/MS/2023/School/515 dated 26/10/2023 (copy enclosed), have not been complied so far.

In view of above, **Fire Safety Certificate (FSC) cannot be renewed at this stage.** Therefore, you are requested to rectify the shortcomings and re-submit for further consideration in the matter.

Encl: As above.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.

C-34.
C-39

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/2023/SCHOOL/515

Dated. 26.10.2023

To,

The Principal,
Lady Irwin Sr. Secondary School,
Srimant, Madhav Rao Scindia Marg,
New Delhi.

Sub: Regarding renewal of FSC in r/o Lady Irwin Sr. Secondary School at Srimant Madhav Rao Scindia Marg, New Delhi.

Sir,
This has reference to your Email <ladyirwinschool_1927@yahoo.com> dated 29/09/2023, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 16/10/2023 in the presence of Sh. S.K. Chatterjee and the following shortcomings were observed in auditorium :-

1. Hose reel found nonfunctional.
2. Overhead Pump not provided.
3. Overhead fire water tank of 5,000 liter capacity is required against the 1000 liter as provided.

In view of above, Fire Safety Certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department.

Yours faithfully

(Anil Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.