

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/EH/2025/SZ/205

Dated: 21/05/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Laidback Café a unit of World of Shalom Restaurants Pvt. Ltd. at Unit No. R-04B, 5th floor, Plot No. 6, Vegas Mall, Dwarka, New Delhi- 110078, running at 5th floor in a building comprised of four tier basement, ground plus five upper floors, owned/occupied by World of Shalom Restaurants Pvt. Ltd., was issued FSC by this department vide Letter No. F.6/DFS/MS/SZ/2022/EH/437 dated 30.09.2022. The Restaurant building was re-inspected by the officer concerned of this department on dated 15.05.2025 in the presence of Mr. Dhiraj Arora, and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (5th floor only) is fit for occupancy class Group "D" Assembly Building" w.e.f. 21/05/2025 and valid up-to 31.03.2028, accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.
 Issued on 21/05/2025 at New Delhi.


 (Anu Garg)
 Director
 Delhi Fire Service
 07/04

Online application Id 2025032704700 dated 01.05.2025

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

: -for information regarding use of basement.

Conditions for validity of Fire Safety Certificate:-

1. This FSC is valid only for 5th floor.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. Basement strictly shall be used as per BBL.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building: M/s Laidback Café a unit of World of Shalom Restaurants Pvt. Ltd. at Unit No. R048, 5th floor, Plot No. 6, Vegas Mall, Sec-14, Dwarka, New Delhi-78
2. Building is comprised of : Basement, ground plus three upper floors
3. Type of Occupancy : Group D (Assembly) Restaurant running at 5th floor of Vegas Mall
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/SZ/2022/EH/437 dated 30.09.2022
6. Fire Safety directives letter No : N/A
7. Date of inspection : 15.05.2025
8. Name of Inspecting Officers : A.D.O. R.K. Yadav (JKP)
9. Name and designation of officers
From the building side : Mr. Dheeraj Arora
10. Year of Construction : 2022
11. Applicant's letter No. : MHA Portal ID 2025032704700 dated 01.05.2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirements As per Old FSC	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 m	Provided	M/R
	• Gate width	6.0 m	Provided	M/R
	• Width of internal road	6.0 m	Provided	M/R
2.	Number, Width, Type & Arrangement of Exits (Common with Mall)			
	a. Number of staircases			
	• Upper Floors	03 nos.	03 Nos. (Provided by Mall)	N/A
	• Basements	N/A	12 Nos. (Provided by Mall)	N/A
	b. Width of staircases			
	• Upper Floor	1.5 m each	Provided by Mall	MR
	• Basements	N/A	Provided	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	2.0 & 1.5 m	2.0 m × 2	MR
3.	Compartmentation (Common with Mall)			
	• Fire check door	N/A	Provided by Mall	N/A
	• Sealing of electrical shafts	N/A	Provided by Mall	N/A
	• Fire Rating of shaft door	N/A	Provided by Mall	N/A
	• Water Curtain	N/A	Provided by Mall	N/A
	• Fire Dampers	N/A	Provided by Mall	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	12 a/c per hour	Provided by Mall	MR
5.	Fire Extinguishers			
	• Total numbers in restaurant	8 no.'s	Provided	M/R
	• Types	ABC/CO ₂	ABC- 04 & Co2- 04	M/R
	• IS marking	ISI marked	Provided	M/R
6.	First-Aid Hose Reels (Common with Mall)			
	• Total numbers at each floor	Required	Provided by Mall	M/R
	• Length of hose reel hose	36 mtrs	Provided by Mall	M/R
	• Nozzle diameter	5 mm	Provided by Mall	M/R

NJL

7.	Automatic fire detection and alarming system in restaurant			
	<ul style="list-style-type: none"> Type of detectors Smoke/Heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke/Heat Control Room	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Provided	Provided by Mall	M/R
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors/Restaurant Sprinkler above false ceiling 	N/A	Provided	N/A
		Required	Provided	M/R
		Required	Provided	M/R
11.	Internal Hydrants (Common with Mall)			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	150 MM	150 MM	M/R
		01 no's	03 no's Provided by Mall	M/R
		01 no's	Provided by Mall	M/R
12.	Yard Hydrants (Common with Mall)			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	Provided by Mall	N/A
		N/A	Provided by Mall	N/A
13.	Pumping Arrangements (Common with Mall)			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access 	2850 LPM	Provided by Mall	MR
		120 m	Provided by Mall	MR
		02	Provided by Mall	MR
		180 LPM (02 nos. + water Curtain Pump 2280 LPM)	Provided by Mall	MR
		120 m	Provided by Mall	MR
		2850 LPM	Provided by Mall	MR
		120 m	Provided by Mall	MR
		Required	Provided by Mall	MR
		Required	Provided by Mall	MR
	<ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM	Provided by Mall	N/A
		40 m	Provided by Mall	N/A
		Required	Provided by Mall	N/A
		Required	Provided by Mall	N/A
14.	Captive Water Storage for fire-fighting (Common with Mall)			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	4,00,000 ltrs. (by Mall)	N/A
		N/A	Provided by Mall	N/A
		N/A	Provided by Mall	N/A
		N/A	Provided by Mall	N/A
		20,000 ltrs	Provided by Mall	M/R
15.	Exit Signage.	Required	Provided by Mall	M/R
16.	Provision of Lifts (Common with Mall)			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	Provided by Mall	N/A
		N/A	Provided by Mall	N/A
		N/A	Provided by Mall	N/A
		N/A	Provided by Mall	N/A
		N/A	Provided by Mall	N/A


NH

Standby power supply	Required	Provided by Mall	M/R
Refuge Area. (Common with Mall)			
➤ Total Area	N/A	Provided	N/A
➤ Location	N/A	Provided	N/A
Fire Control Room (Common with Mall)			
<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	Provided by Mall	N/A
	N/A	Provided by Mall	N/A
	N/A	Provided by Mall	N/A
	N/A	Provided by Mall	N/A
	N/A	Provided by Mall	N/A
20. Special Fire Protection System for Protection of special Risks, if any:	N/A	Provided by Mall	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.



Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/SZ/2022/EH/437 dated 30.09.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note: - The restaurant running at 5th floor in Vegas Mall. Vegas Mall building having separate FSC by this department vide letter No. F.6/DFS/MS/SZ/2022/62 dated 09.12.2022. Area of the restaurant is 151 sqm. and total seating capacity comes out be 84 ($151/1.8 = 84$).


 Signature of the Inspecting Officer
 Name- R.K. Yadav
 Designation- ADO (JKP)

~~DO (SW)~~

DO
15/5/25

CR/ 
16/5/2025
Director 
17/5/25

FT letter is put up for sign please

DIRECTOR 

Uploading


20/5/2025