

C-39

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/NDZ/2025/ 336

Dated: 12/8/2025

To,

The Manager,  
M/S Lash Café ( A Unit of Pepsu LLP),  
39, First floor, East of Kailash,  
New Delhi-65.

Sub: Issuance of FSC (Fire Safety Certificate) in r/o M/S Lash Café ( A Unit of Pepsu LLP), 39, First floor, East of Kailash, New Delhi-65.


Sir,

This has reference to ID No. 2025071611415 dated 17/07/25, on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 28/07/2025 in the presence of Mr. Uzzawal and the following shortcomings were observed:-

1. Hose reel, hydrant, MOEFA and pump found nonfunctional.
2. Overhead tank is provided of 10,000 liter capacity against the requirements of 20,000 liter.
3. Alternate staircase of iron made found removed.

In view of above, **the case is rejected and Fire Safety Certificate (FSC) cannot be renewed at this stage.** Therefore, you are requested to rectify the above shortcomings and re-submit for further consideration in the matter.

Yours faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station,  
New Delhi.