



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/Hospital/2025/SZ/ 124

Dated: 26/03/2025

To

The Executive Engineer (Elect),  
Central Public Works Department,  
Safdarjung Hospital Electrical Division,  
Safdarjung Hospital, New Delhi-110029

**Sub: Inspection report in r/o Laundry Block located at Safdarjung Hospital Complex, New Delhi-110029**

Sir,

This has a reference to your letter No. 19(1)/D.B./SJHED/2024-25/1689 dated 25/11/2024, received through outdoor diary No. 9630 dated 27/11/2024 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 17/03/2025 to verify the availability & operability of fire safety arrangements in the presence of Sh. Vivek Kr. Gupta (JE/Elect.). During course of inspection, the shortcomings observed are as below.

1. Escape route (stairs & corridors) found partially blocked with material.
2. First-Aid hose-reel found non-functional.
3. Hose boxes near internal & yard hydrants found empty.
4. Exit signage found removed at some places.

In view of above shortcomings, renewal of fire safety certificate cannot be considered at this stage. You are requested to rectify the shortcomings under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)  
Director  
Ph. 011-23414000

01/08/25

Copy to: -

1. The Medical Superintendent, Safdarjung Hospital & Vardhman Mahavir Medical College, Safdarjung Hospital, New Delhi-110029.