

C/47

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/SC4004222
To,

Dated: 15/04/2025

The Principal,
Laurel Convent School,
D-2/56, Budh Vihar, Phase-I,
Delhi-110086.

Sub: Issue of FSC in r/o Laurel Convent School, D-2/56, Budh Vihar, Phase-I, Delhi-110086.

Sir,

Kindly reference to online e-mail dated 03.03.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 19.03.2025, in presence of **Mrs. Joyti (Principal)** o ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. Terrace door of staircase is opening in opposite side.
2. Hose reel provided but not functional
3. Terrace Fire pump with capacity of 450 LPM provided but not functional.
4. Terrace fire pumps were not found in auto mode.
5. 5000 ltrs Over Head water captive tank provided against the required capacity of 10,000 ltrs
6. The required exit signage is not provided.
7. One more floor found added over existing building making it ground + 03 upper floors
8. Copy of approved building plan or set as built from MCD enrolled architect may kindly be provided to adjudge the fire safety requirement further.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

Yours faithfully

3/4/2025
(Virendra Singh)
Chief Fire Officer
For DIRECTOR
Ph; 011-23414000