

C-35

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI

No. F6/DFS/MS/School/WZ/2025/206

Dated: 04/03/2025

FIRE SAFETY CERTIFICATE

Certified that the Laurel High School, located at Behind IDPL CHBS Society, Pitampura Village, New Delhi-110034., comprised of Ground plus Three Upper Floors, owned/occupier by Millennium Child Education Society (Regd), 129 Harsh Vihar, Pitampura, Delhi-110034, was issued FSC vide letter No F6/DFS/MS/School/WZ/2022/235 dated 07/03/2022. The premises was re - inspected by the officer concerned by this department on 20/02/2025 in the presence of Sh. Amit Kumar and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. That the building/premises have deemed complied with fire prevention and fire safety requirements in accordance with DOE 3298-3398 dated 01/03/2011/NBC Part-IV and the building/ premises is fit for occupancy class "Educational" (Group -B) with effect from 04/03/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below

Issued on 04/03/2025 at New Delhi.

(Anul Garg)
Director

Copy to:

1. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi 110054.
2. The Principal, Laurel High School, located at Behind IDPL CHBS Society, Pitampura Village, New Delhi-110034. Email ID- laurelhigh2@gmail.com.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. All the means of escapes/exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	Laurel High School, located at Behind IDPL CHBS Society, Pitampura Village, New Delhi-110034.		
2.	Type of Occupancy	Educational		
3.	Type of Case	Renewal		
4.	Details of previous NOC	F6/DFS/MS/School/WZ/2022/235 dated 07/03/2022.		
5.	Fire Safety directives letter No	DOE 3298-3398 dated 01/03/2011/NBC Part-IV		
6.	Date of inspection	20/02/2025		
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)		
8.	Name and designation of officers from the building side	Sh. Amit Kumar		
9.	Year of Construction	2007 (As per previous Inspection Report dated 24/02/2024)		
10.	Applicant's letter No.	Email dated 18/02/2025.		
The said school building is comprised of Ground plus Three Upper Floors.				
S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	Directly accessible from road	MR
	• Gate width	05 mts	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50 mts each	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02 Provided	MR
	e. Width of Corridor	1.5 mts	1.78 mts	MR
	f. Door Size	1.0 mts	Old case	MR(old case)
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	07 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 mts	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	01	MR
	• Hose Box	01	01	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	02 x 450 LPM	Provided	MR
	➤ Head of the pump	40 LPM each	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000 lts	5,000 lts	MR
		Required	Provided	MR
15	Exit Signage.	Not Applicable		
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/School/WZ/2022/235 dated 07/03/2022, renewal under DOE 3298-3398 dated 01/03/2011/NBC Part-IV is recommended.

ADDO MN
10/3/2025

(Signature)
24/03/2025

(Signature)
21/2/2025

Signature of the Inspecting Officer
Sarabjeet Singh ADO (MN)

(Signature)
25/2/2025

(Signature)
25/2/2025
Director
20/2/25
ADDO MN

Sir, F. T is put up for
your kind perusal & signature please!

(Signature)
Director
20/2/25

(Signature)
04/3/2025

10.7.3.1113
Dated...24/2/2025