



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

7/11  
आजादी का  
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2025/ 890

Dated:- 11/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Lavi Public School Located at Plot No. 141, Main Narela Road, Village Ghevra, New Delhi-110081 comprised of Ground + 03 Upper Floors only, owned/occupied by Lavi Public School, was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/WZ/2022/718 dated 28/06/2022. The said premise was re-inspected by the officer concerned of this department on 03/07/2025 in the presence of Sh. Parveen Rana (Gen. Secretary) and found that the premises/building have deemed complied with the fire prevention and fire safety requirements in accordance with D.O.E. Cr. No. 3298-3398 dated 01/03/2011 and that the school building is fit for occupancy class "Educational Building" Group B" with effect from 11/07/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 printed below.

Issued on 11/07/2025 at New Delhi by.

(Atul Garg)  
Director

Tel. No. 011-23414000

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Lavi Public School, Plot No. 141, Main Narela Road, Village Ghevra, New Delhi-110081.

**Conditions for validity of Fire Safety Certificate :-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

# INSPECTION REPORT

W-24

1. Name and address of the building: Lavi Public School (B.K. Rana Education and Welfare Society (Regd.) Located at Plot No. 141, Main Narela Road, Village Ghevra, Delhi.
2. Type of Occupancy : Educational (G + 03 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/WZ/2022/718 dated 28/06/2022
5. Fire Safety directives Letter No. : D.O.E. Cr. No. 3298-3398 dated 01.03.2011
6. Date of inspection : 03/07/2025
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer  
from the building side : Sh. Parveen Rana (Gen. Secretary)
9. Year of Construction : 2003 & 2020-2021
10. Applicant's letter No. : nil dated nil  
The school building is comprised of ground plus three upper floors.

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements as per D.O.E. Cr. No. 3298-3398 dated 01.03.2011/as per earlier FSC issued dated 28/06/2022	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	03	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1.5 m x 2 & 1.2 m x 1	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	ABC & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR



6.	First Aid Hose Reels				
	• Total numbers on each floor	9)	Provided		
	• Length of hose reel hose	30 m	Provided		MR
	• Nozzle diameter	5 mm	Provided		MR
7.	Automatic fire detection and alarming system				
	• Type of detectors	NA	NA		NA
	• Location of Main Panel	NA	NA		NA
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	NA	NA		NA
	• Hooters' Location	NA	NA		NA
8.	MO/PA	NA	NA		NA
9.	Public Address System	NA	NA		NA
10.	Automatic Sprinkler System				
	• Basements	NA	NA		NA
	• Upper Floor	NA	NA		NA
	• Sprinkler above false ceiling	NA	NA		NA
11.	Internal Hydrants:				
	• Size of riser/down-comer	NA	NA		NA
	• Number of hydrants per floor	NA	NA		NA
	• Hose Box	NA	NA		NA
12.	Yard Hydrants				
	• Total number of hydrants	NA	NA		NA
	• Hose Box	NA	NA		NA
13.	Pumping Arrangements:				
	• Ground Level				
	• Discharge of main pump	NA	NA		NA
	➤ Head of main pump	NA	NA		NA
	➤ Number of main pumps	NA	NA		NA
	➤ Jockey pump out put	NA	NA		NA
	➤ Jockey pump head	NA	NA		NA
	➤ Standby Pump out put	NA	NA		NA
	➤ Standby Pump Head	NA	NA		NA
	➤ Auto Starting/Manual stopping	NA	NA		NA
	➤ Pump House Access	NA	NA		NA
	• Terrace level				
	➤ Discharge of pump	450 lpm	Provided		MR
	➤ Head of the pump	40 m	Provided		MR
	➤ Power supply	Required	Provided		MR
	➤ Auto starting of pump	Required	Provided		MR
14.	Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA		NA
	➤ Draw off connection	NA	NA		NA
	➤ Fire service inlet	NA	NA		NA
	➤ Access to tank	NA	NA		NA
	• Overhead Tank capacity	10,000 ltrs.	Provided		MR
15.	Exit Signage	Required	Provided		MR
16.	Provision of Lifts				
	➤ Pressurization of Lift Shaft	NA	NA		NA
	➤ Pressurization of lift lobby	NA	NA		NA
	➤ Communication in lift Car	NA	NA		NA
	➤ Fireman's Grounding Switch	NA	NA		NA
	➤ Lift Signage	NA	NA		NA
17.	Standby power supply				
18.	Refuge Area				
	➤ Total area	NA	NA		NA
	➤ Location	NA	NA		NA

n/26

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Cr. No. 3298-3398 dated 01/03/2011, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2022/718 dated 28/06/2022 is recommended.

Accordingly DFA is put up for approval please.

*Bill to*  
01/07/25  
Aman Kumar Lathar  
ADO (JWP)

*OCFO (WZ)*

*AD  
WZ*

*01/07/25*

*CFD*

*01/07/25*

*Director*  
*01/07/25*  
*AD/JWP*

Sir, F.T. letter is put-up for your signature pl.

*Director*  
*01/07/25*

*Bill to*  
*Director*  
*AD(JWP)*