




No. F6/DFS/MS/GH/SZ/2026/ 636

Dated: 15/07/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Lavish Quarter (Guest House) located at Khasra no. 435, Lal Doora, Abadi Mahipalpur, Village Mahipalpur, New Delhi-37, comprised of Basement + Ground + 03 upper floors: Basement- Parking, Ground floor- 03 Guest rooms, 1st floor - 05 Guest rooms, 2nd floor- 05 Guest rooms, 3rd floor - 05 Guest rooms, owned & occupied by Lavish Quarter have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of Delhi Fire Service on 03/07/2026 in the presence of Sh. Summit (Manager) and the building/premises is fit for occupancy of Group 'A (Residential) sub division A-1, having 18 Guest Rooms (Basement-Parking, Ground floor- 03 Guest rooms, 1st floor - 05 Guest rooms, 2nd floor- 05 Guest rooms, 3rd floor - 05 Guest rooms) with effect from 15/07/2026 and valid upto 31.03.2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire service Rules, 2010 printed below.

Issued on 15/07/2026 at New Delhi by


(A. K. Malik)

Chief Fire Officer

Reference: etl.mcdonline application no. 2026042906018.

Conditions for the validity of Fire Safety Certificate

1. The means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of an emergency.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".
9. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

120

INSPECTION REPORT						
1	Name & address of the building		M/s Lavish Quarter (Guest House) located at Khasra no. 435, Lal Doora, Abadi Mahipalpur, Village Mahipalpur, New Delhi-37.			
2	Building is comprised of		Basement + Ground + 03 upper floors Basement- Parking Ground floor- 03 Guest rooms + Reception + office 1st floor - 05 Guest rooms 2nd floor - 05 Guest rooms 3rd floor - 05 Guest rooms			
3	Type of occupancy		Residential, 'Group-A' (Guest House)			
4	Type of case		New Case			
5	Details of Previous FSC		Nil			
6	Fire Safety directive letter no.		Nil			
7	Date of inspection		03/07/2026			
8	Name of the inspecting officers		Rajesh Kumar Shukla ADO (Jangpura)			
9	Name of the designation of officer from the building side		Sh. Sumit (Manager)			
10	Year of construction		2000			
11	Applicant's letter no.		etl.mcdonline application no. 2026042906018			
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33		Requirement as NBC/UBBL-2016	Provided at Site	Remarks MR/NMR	
1	Access to building					
	A	Road width	6.0 m	6.0 m	MR	
	B	Gate width	NA	NA	NA	
	C	Width of internal road	NA	NA	NA	
2	Number, Width, Type and Arrangement of Exits					
	A	Number of staircases				
		a	Upper floor	2 nos.	Provided	MR
		b	Basement	2 nos.	01 no. + 01 ramp	MR
	B	Width of staircases				
		a	Upper floor	1.50 m each	1.50 m each	MR
		b	Basement	1.50 m each	1.50 m, ramp -3.5 m	MR
	C	Protection of exits				
		a	Fire check door	NA	Provided	NA
		b	Pressurization	NA	NA	NA
	D	No. of continuous staircases to terrace		2 nos.	2 nos.	MR
	E	Width of corridor		1.50 m (Single loading)	Provided	MR
	F	Door size		1.50 m	1.50 m (final exits)	MR
3	Compartmentation					
	A	Fire check door		NA	NA	NA
	B	Sealing of electrical shafts		NA	NA	NA
	C	Fire rating of shaft door		NA	NA	NA
	D	Water curtain		NA	NA	NA
	E	Fire dampers		NA	NA	NA
4	Smoke Management System.(Required as per clause 7.31 (x) UBBL 2016 (amended))					
	A	Basement		Natural/ Mechanical	Exhaust fans	MR
	B	Upper floor		Natural/ Mechanical	Exhaust fans	MR

5.	Fire Extinguisher				
	A	Total numbers	15 nos.	15 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI marked	Provided	MR
6	First-Aid-Hose Reels				
	A	Total numbers of each floor	01 no.	Provided	MR
	B	Length of hose reel hose	30 m	Provided	MR
	C	Nozzle diameter	5 mm	Provided	MR
7	Automatic Fire Detection And Alarming System (required as per clause 7.31.viii, UBBL 2016).				
	A	Type of detectors	CO detectors	Provided	MR
	B	Location of main panel	Ground	Provided	MR
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	Required	Provided	MR
	E	Hooters	Audible in entire building	Provided	MR
8	MOEFA		Required	Provided	MR
9	Public Address System.		NA	NA	NA
10	Automatic Sprinkler System.				
	A	Basement	Required	Provided	MR
	B	Upper floor	NA	Provided	NA
	C	Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants				
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants.				
	A	Total number of hydrants	NA	NA	NA
	B	Hose box	NA	NA	NA
13	Pumping Arrangements.				
	A	Ground Level			
	a	Discharge of main Pump	NA	NA	NA
	b	Head of Main Pump	NA	NA	NA
	c	Number of main pumps	NA	NA	NA
	d	Jockey pump out put	NA	NA	NA
	e	Jockey pump head	NA	NA	NA
	f	Standby pump out put	NA	NA	NA
	g	Standby pump Head	NA	NA	NA
	h	Auto Starting /Manual stopping	NA	NA	NA
	i	Pump house access	NA	NA	NA
	B	Terrace Level			
	a	Discharge of pump	900 LPM	Provided	MR
	b	Head of the Pump	40 m	40 m	NA
	c	Power supply	Required	Provided	MR
	d	Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	NA	NA	NA
	B	Draw-off connection	NA	NA	NA
	C	Fire service inlet	NA	NA	NA
	D	Access to tank	NA	NA	NA
	E	Overhead tank capacity	10,000 ltrs	20,000 ltrs	MR

M/s Lavish Quarter (Guest House) located at Khasra no. 435, Lal Doora, Abadi Mahipalpur, Village Mahipalpur, New Delhi-37.

16	Provision of Lifts.			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	Required	Provided
	E	Lift signage	Required	Provided
17	Standby Power Supply		Required	Provided
18	Refuge Area.			
	A	Total area	NA	NA
	B	Location	NA	NA
19	Fire Control Room			
	A	Detector system panel	NA	NA
	B	Flow switch panel	NA	NA
	C	PA system panel	NA	NA
	D	Battery backup	NA	NA
	E	Building floor plans	NA	NA
20	Special Fire Protection Systems for Protection of Special Risks, If Any:		NA	NA

LEGENDS:-Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

Note:-The owner has submitted an affidavit & photos (place at C/28 to 31) stating that rooms on one side of the corridor has been sealed and now the Guest House has a single loading design. The access road also found widened and now it meets the requirement of 6 meters.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

The shortcomings issued to the Guest House by this department vide letter no. F6/DFS/MS/GH/SZ/2026/544 dated 03/06/2026 has been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, **it is recommended to grant Fire Safety Certificate under Rules 35 of Delhi Fire Service Rules 2010.** Last date of disposal of this application is 16/07/2026.

[Signature]
06/7/26

Signature of the Inspecting Officer
Name Rajesh Kumar Shukla
Designation ADO (Jangpura)

DO (South)

[Signature]
27/26
Ravinder Singh

[Signature]
8/2/26
A.K. MALIK

fr. Dr. Cfo to some. *[Signature]*