



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2025/ 275

Dated: 06/06/2025

To,

The Joint Commissioner of Police (Lic.),
1st floor, Police Station Defence Colony,
New Delhi – 110024.

Subject: - Regarding grant of Fire Safety Certificate in r/o Dev Palace Guest House located at Plot No. 641 B- 1 first floor, Ram Nagar Near Bank of Baroda, Shadara, Delhi – 110031.

Sir,

This has a reference to MCD application No. 2025050808115 dated 14/05/2025 on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 23/05/2025 in the presence of Mr. Devinder Sharma (Owner) and observed that building comprised of Stilt, Ground plus three upper floors.

Following shortcomings were observed during time of inspection:

1. Fire Check door found removed.
2. Fire Extinguisher found empty.
3. CO/Smoke detector found removed.
4. Exit & floors Signage's found removed in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. In addition to above details mentioned in online application is not matching with the actual building the application needs correction in respect of total number guest rooms etc. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
o/c DELHI FIRE SERVICE

Copy to:-

1. Mr. Devinder Sharma (Owner), Dev Palace Guest House located at Plot No. 641 B- 1 first floor, Ram Nagar Near Bank of Baroda, Shadara, Delhi – 110031.