



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/BNQT/2025/EZ/ 105

Dated: 06/06/2025

To,

The Joint Commissioner of Police (Lic),
1st Floor, Defence Colony Police Station,
New Delhi- 110049.

Sub:- Regarding renewal of Fire Safety Certificate in r/o M/s Le Diamonds Banquet
located at Plot No. 5, DDA Community Centre, Yamuna Vihar, Delhi- 53.

Sir,

This has reference to online application received through MCD portal vide ID- 2025051008294 dated 13/05/2025 on the subject cited above. In this connection, it is to inform you that the above said assembly building was re-inspected by officer concerned of this department on 26/05/2025 in presence of Sh. Anil Kumar and observed that of the shortcomings issued by this department vide letter No.F6/DFS/MS/BNQT/NDZ/2025/77 dated 08/05/2025 are still not complied (copy enclosed).

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Encl: as above

Yours Faithfully

Livp
06/06/25
(S.K. Dua)

Dy. Chief Fire Officer
Delhi Fire Service

de n

Copy to:-

1. The Owner/ Occupier, M/s Le Diamonds Banquet located at Plot No. 5, DDA Community Centre, Yamuna Vihar, Delhi- 53.
Ref- MCD Online ID No. 2025051008294.

2102

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/BNQT/NDZ/2025/ 77

Dated: 08/05/2025

To

The Joint Commissioner of Police (Licensing),
1st Floor, Police Station Defence Colony,
New Delhi.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s LE DIAMONDS located at Plot No.- 5, GF & FF, DDA Community Centre, Yamuna Vihar, Delhi - 110053.

Sir,

This has reference to online application ID No. 2025032804828 dated 11.04.2025 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 01.05.2025 in presence of Mr. Ashish Jain and it was observed that building is comprised of Basement + ground + 02 upper floors but banquet hall is running at ground & 1st floor only. During inspection, following shortcomings were observed:

1. First aid hose reel provided but not functional.
2. Automatic fire detection and alarming system provided but not functional.
3. MOEFA provided but not functional.
4. PA system provided but not functional.
5. Fire pump not on auto start mode.
6. Exit signages and lift signages are not adequately provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
Tel: 01123414000
10/05/25

Copy to:-

The Manager,

M/s LE DIAMONDS at Plot No.-5, GF & FF, DDA Community Centre, Yamuna Vihar, Delhi - 110053.