



c 116
11/11/2025

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/BNQT/NDZ/2025/ 154

Dated: 03/09/2025

To,

Sh. Shuk Mal Chand Jain,
M/s Le Diamonds Banquet Hall
Plot No. 05, Community Hall Center, Yamuna Vihar,
Delhi-110053

Subject:-Regarding renewal of Fire Safety Certificate in r/o M/s Le Diamonds Banquet Hall located at Plot No. 05, Community Hall Center, Yamuna Vihar, Delhi-110053.

Sir,

This has reference to MCD application ID No. **2025071111269** dated **02/08/2025** on the subject cited above. In this connection, the premises have been re-inspected by the officer concerned of this department on dated 18/08/2025 in presence of Mr. Anil, Manager. The Banquet Hall building is comprised of basement, ground plus two upper floors. The following shortcoming was observed during the time of inspection.

1. Three staircases provided which width 02 meters, 1.50 meters & 01 meter against the requirement of at least two staircases of width 02 meter each.
2. Fire check doors not provided.
3. Automatic Fire Alarm System provided but not functional.
4. MOEFA provided but not functional.
5. Smoke Management system in the basement and upper floors not provided.
6. Fire pump not on auto start mode.
7. Exit signages and lift signages are not adequately provided.
8. Pressurization of lift Shaft and lift lobby not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

21/9/2025

dc
R. (VIRENDRA SINGH)
CHIEF FIRE OFFICER