0/23



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2025/ 380

Dated: 12/08 /2025

To,

The Authorized Signatory, M/s Le Fric Beaute Care LLP, 1-105, Sector 5, DSIDC Bawana Industrial Area, Delhi- 110039.

Sub: - <u>Inspection report in r/o M/s. Le Fric Beaute Care LLP located at L-105, Sector-5, DSIDC Bawana Industrial Area, Delhi- 110039.</u>

Sir,

Please refer to letter no. nil received through outdoor diary no. 2962 dated 23/06/2026 on the subject cited above. In this connection, it is to inform you that the above said industrial building was inspected by the officer concerned by this department on 16/07/2025 in the presence of Sh. Abhas to check the functioning of Fire Safety arrangements provided in the building.

During inspection, it has been observed that the industrial building is comprised of Basement + Ground + 02 Upper Floors. Following **shortcomings** were observed at the time of inspection:-

- 1. Smoke management system found removed in basement.
- 2. First aid hose reel found provided but not functional.
- 3. Terrace level pump found provided but not functional.

In view of the above **shortcomings**, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall is at the risk and liabilities of the Owner/ Occupier.

Yours faithfully,

(Virendra Singh) Chief Fire Officer

dea

Copy to :-

 The Dy. Drugs Controller/ Licensing Authority, Drug Control department, F-17, Karkardooma, Delhi- 110032.