



C79



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No.F.6/DFS/MS/BNQT/2025/NDZ/26

Dated: 17/02/2025

To,

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s Le Paradise Banquet Hall located at 341/6B-1, Kanti Nagar Delhi-110051.

Sir,

This is in reference to MCD online application portal ID.2022050309260 dated 20/01/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned banquet Hall from fire safety point of view in presence of Mr. Vijay Goyal on dated 12/02/2025. The building comprised of lower ground floor, ground floor and two upper floor but banquet hall is running on ground floor only. The following shortcomings were observed during the time of inspection.

1. First-Aid Hose Reels provided but not functional.
2. Down-comer provided but not functional.
3. Terrace pump provided but not functional.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

2. 4/100