



८११

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2026/ 375

Dated: 24/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Le Roi Guest House, 2206, Chuna Mandi, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026032503548 dated 25/03/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 04/04/2026 in the presence of Sh. Amit, Manager and following shortcomings were observed: -

1. Fire Check Door was not provided at 2nd Floor.
2. Smoke Management system was not provided in the building.
3. First-aid Hose reel found damaged on 3rd Floor.
4. Carbon Monoxide detectors found removed.
5. Overhead Water Storage tank Capacity was 35,000 Ltrs. against the required capacity of 50,000 Ltrs.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


24/4/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s Le Roi Guest House, 2206, Chuna Mandi, Paharganj, New Delhi - 110055.

01/05/26