

c-58

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No.F6/DFS/MS/WZ/School/2025 /681

Dated: 22/08/2025

To,

The Principal,
Smt. Lilawanti Saraswati Shishu Mandir,
FB, Block, Tagore Garden,
New Delhi 110027.

Sub: Regarding Issuance of Fire Safety Certificate in respect of Smt. Lilawanti Saraswati Shishu Mandir, FB, Block, Tagore Garden, New Delhi-110027.

Sir,

With reference to your letter No. SSM/TG/2024-25/568 dated 14/07/2025, received through outdoor dairy No. 3740 dated 15/07/2025, on the subject cited above. In this connection, it is to inform you that the said premises/building was re-inspected by the officer concerned of this department on 28/07/2025, in the presence of Sh. Naresh Kumar to check the shortcomings already issued by this department vide letter No.F6/DFS/MS/School/WZ/2024/522 dated 16/08/2024 & F6/DFS/MS/WZ/School/2025/400 dated 15/05/2025.

However the status of shortcomings are as under.


S. no.	Shortcomings	Status
1.	Width of staircases is 1.5mtr & 1.20mtr are provided against requirement of 2X 1.5m each, & alternate staircase not connected with 2 nd floor.	Not Rectified (width of staircase is 1.2m to 1.5m it should be clear 1.5m)
2.	First-Aid Hose reels are provided but not functional.	Rectified
3.	Main fire pump capacity of 450 LPM is provided but not functional.	Rectified
4.	Overhead water storage tank capacity of 10,000 ltr is not provided.	Rectified.
5.	Exit signage's are not provided.	Rectified

In view of above shortcomings, the **application for issuance of fire safety certificate is not considered at this stage & rejected.** The occupancy of the building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier. The licensing authority /statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully,



Virendra Singh
Chief Fire Officer



Copy to: -

1. The Director, Directorate of Education, Old secretariat, Delhi-110054.