

d/b1

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI


No. F6/DFS/MS/School/WZ/2025/ 1206

Dated: 29/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Smt. Lilawanti Saraswati Shishu Mandir, located at FB, Block, Tagore Garden, New Delhi-110027, is running in total two blocks BLK -1 = ground + 01 upper floor & BLK-2 = ground + 03 upper floors both are interconnected, 'was issued FSC vide letter No F6/DFS/MS/School/2013/583 dated 19/07/2013 for (BLK-01) ground plus one upper floor only. The premises was re - inspected by the officer concerned by this department on 12/09/2025 in the presence of Sh. Naresh Kumar and observed that all the fire prevention & fire safety arrangements provided in the premises found in good working condition. The building/premises have complied with fire prevention and fire safety requirements in accordance with DOE circular 3298-3398 dated 01/03/2011/NBC Part-IV and the building/premises is fit for occupancy class "Educational" (Group -B) with effect from 29/09/2025... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Condition mentioned below.

Issued on 29/09/2025..... at New Delhi.


Virendra Singh
Chief Fire Officer

Copy to:

1. The Director, Directorate of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi 110054.
2. The Principal, Smt. Lilawanti Saraswati Shishu Mandir, located at FB, Block, Tagore Garden, New Delhi-110027.

Conditions for the validity of FSC:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

Name & address of the building	Smt. Lilawanti Saraswati Shishu Mandir, located at FB, Block, Tagore Garden, New Delhi-110027.
2. Type of Occupancy	Educational
3. Type of Case	New
4. Details of previous NOC	Nil
5. Fire Safety directives letter No	NBC-Part-IV/DOE Circular 3298-3398 dated 01/03/2011
6. Date of inspection	12/09/2025
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Naresh Kumar
9. Year of Construction	1991 G + 1 & 2018 G + 3 (As per previous inspection report dated 02/08/2024)
10. Applicant's letter No.	Letter No. SBM/TG/2025-26/591 dated 11/08/2025.

The said school is running in total two blocks BLK -1 = ground + 01 upper floor only & BLK-2 = ground + 03 upper floors both are interconnected, was issued FSC by this department vide letter No. F6/DFS/MS/School/2013/583 dated 19/07/2013 for BLK-01 Ground plus one upper floor only.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.5m x 2	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5 m	Provided	MR
	f. Door Size	1.0 m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers			
	• Total numbers	12 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR

7	Automatic fire detection and alarming system.			NA
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	Provided down comer	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Required	Provided	MR
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection. Earlier all the shortcomings issued by this department have been complied by school management.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

19/AD0/MN
15/09/25

~~Dy CPO (WZ)~~

~~Signature of the Inspecting Officer~~
~~Sarabjeet Singh ADO (MN)~~

~~18/9~~

DCFO/S17-WZ
Dated 17-09-25

~~CFO/18/9/2015~~

~~Principal Director~~

~~CFO to 18/9/25~~

~~Dy CPO~~
~~ADO (MN)~~

~~CFO/19/9/2015~~

Sir, F. T is put up for your kind personal & signature please.

~~C.P.O./18/9/2015~~

~~18/9/25~~