

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2025/SZ/1366

Dated 08/08/2025

To,

Mr. Ravinder Kaur,
Lilywhite Hotel, Khasra No 772, 773 & 774,
Chattarpur, New Delhi 110074.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Lilywhite Hotel, Khasra No 772, 773 & 774, Chattarpur, New Delhi 110074.

Sir,

This has reference with your letter, received through DFS outdoor diary no 3848 dated 17/07/2025 on the subject cited above. In this connection it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 26/07/2025 and observed that the shortcoming intimated vide letter of even no 321 dated 04/07/2025 has not been complied yet.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Encl:- As above


(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Ch12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI

No. F6/DFS/MS/EH/NDZ/2025/ 321

Dated: 04/07/2025

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Sub: Regarding renewal of fire safety certificate in respect of Lilywhite Hotel, located at Khasra No. 772,773 & 774, Chattarpur, New Delhi-110074.

Sir,

Please refer to your online application no. 2025060909828 dated 09/06/2025 & 2025060509678 dated 05/06/2025, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 20/06/2025 in the presence of Mr. Amir (Sales) to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above motel is running at ground & 1st floor only, in a building comprised of basement + ground + 01 upper floors. Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

1. First Aid Hose reels are provided but not functional.
2. MOEFA is provided but not functional.
3. Public Address System is provided but not functional.
4. 1620 x 180 LPM pumps are provided but not automode.
5. Exit signage are found removed.

In view of above Shortcomings, the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

(Atul Garg)
Director

Copy to: -

1. The Dy. Health Officer, MCD, Public Health Department, South Zone, green Park, Delhi-110016.
2. The Owner/Occupier, Lilywhite Hotel, located at Khasra No. 772,773 & 774, Chattarpur, New Delhi-110074.