



c 50
गणतन्त्र
सर्वोच्च

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2025/NDZ/ 863

Dated: 04/07/2025

FIRE SAFETY CERTIFICATE

Certified that Little Flowers Public Sr. Sec. School located at Shivaji Park Babarpur Road Shahdra, Delhi-110032 comprised of ground plus four upper floors but school is running Ground plus three upper floor (4th floor's rooms have been sealed by the management), owned/occupied Little Flowers Public Sr. Sec. School was issued FSC vide letter No. F.6/DFS/MS/School/2021/NDZ/916 dated 01/11/2021. The premises was re-inspected by the officer concerned of this department on dated 03/06/2025 in the presence of Mrs. Neha Dua (Principal), and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 262-362 dated 17/01/2005 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' (ground to 3rd floors only) with effect from 04/07/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on.....04/07/2025.....at New Delhi by


(VIRENDRA SINGH)
CHIEF FIRE OFFICER

To:-

The Principal,
Little Flowers Public Sr. Sec. School,
Shivaji Park Babarpur Road Shahdra, Delhi-110032.

Copy to:-

1. The Dy. Director of Education
North-East B-Block Yamuna Vihar, Delhi-110053.
2. The Commissioner, MCD to direct the officer concerned for measuring the height of the building

Conditions for the validity of Fire Safety Certificate

1. FSC is valid for ground to three upper floors only. 4th floor's rooms are sealed may not be used for any purpose failing should be treated null and void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of

INSPECTION REPORT

1. Name & address of the building : Little Flowers Public Sr. Sec. School, located at Shivaji Park, Shahdara Delhi-110032.
2. Building is comprised of : Ground plus four upper floors but school is running ground plus three upper floor (4th floor having two rooms are sealed by the management)
3. Type of Occupancy : Educational
4. Type of Case : Addition/Alteration
5. Details of Previous NOC letter : F.6/DFS/MS/School/2021/NDZ/916 dated 01/11/2021(G+3)
6. Fire Safety direction letter No : Circular no. 22-362dt 17/01/2005 & NBC Part-IV
7. Date of Inspection : 03/06/2025
8. Name of the Inspecting officers : ADO (Shd.) Deepak Kumar
9. Name and designation of Officer from the building side : Sh. Neeta Dua (Principal)
10. Year of Construction : 1980
11. Applicant's letter No : email info@ifpsdelhi.com Dated 22/05/2025

Sr. No	Minimum Standards on fire prevention and fire safety U/R33	Circular/NBC Requirement	Provided at Site	Remarks MR/NMR
01	Access to building.			
	• Road width	06 mtr.	06 mtr.	MR
	• Gate width	4.5mtr.	05 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	2 nos.	08 nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.50 mtr./add. 0.75 mtr.	1.06 mtr, 1.15 mtr, 1.05 mtr, 1.20 mtr, 1.10 mtr up to (G +3) & 1.12 mtr, 1.10 mtr up to (G +1)	MR (accepted earlier)
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 nos.	02 nos.	MR
	e. Width of Corridor	1.50 mtr.	01 mtr.	MR (accepted earlier)
	f. Door Size	01 mtr.	01 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05.	Fire Extinguishers.			
	• Total numbers	16 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-aid-Hose Reels.			
	• Total numbers on each floor	02 nos.	02 nos.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	Provided	N/A
	• Number of hydrants per floor	N/A	01 nos	N/A
	• Hose Box	N/A	Provided	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	➤ Ground Level	N/A	N/A	N/A
	• Discharge of main Pump	N/A	N/A	N/A
	• Head of Main Pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump Head	N/A	N/A	N/A
	• Auto Starting /Manual stopping	N/A	N/A	N/A
	• Pump House Access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 Lpm	450 lpm	MR
	• Head of the Pump	40 mtr.	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Required	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 ltr.	10,000 ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/++A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

Note:- The Management has been submitted undertaking that the two rooms at 4th floor's rooms are sealed and not being used for school and any purpose.

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/792 dated 28/11/2024 have been rectified now.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Circular 262-362 dated 17/01/2005 issued by Director of Education. The FSC issued vide letter no. F.6/DFS/MS/School/2021/NDZ/916 dated 02/01/20025 renewal under rule 35 of the Delhi Fire Service Rules, 2010 is recommended.

Deepak
03/06/2025
Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (Shd)

Deepak
03/06/2025
Dy CTO (NDZ)
KMP
03/06/25

C.F.O.
5/6/2025

A.D.O (Shd)

F.T. Letter is put up for your kind
signature pl
Deepak
30/06/2025

C.F.O.
30/6/2025

mseell