



FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE

[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE

NEW DELHI- 110 001

No. F6/DFS/MS/School/2025/NDZ/ 1327

Dated: 19/11/2025

FIRE SAFETY CERTIFICATE

Certified that the Little Flowers International School located at C-11, 12 (100 feet Road), Kabir Nagar, Delhi-110094, comprised of Basement, Ground plus two upper floors (Old Bldg.) and Ground plus three upper floors (New Bldg.) owned/occupied by Little Flowers International School was issued FSC vide letter No. F.6/DFS/MS/School/2022/NDZ/513 dated 12/05/2022. The premises was re-inspected by the officer concerned of this department on 17/09/2025 in the presence Sh. R. K. Dua (Chairman) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" (Group-B) with effect from 19/11/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on.....19/11/2025.....at New Delhi by.

(Dr. S. K. TOMAR)

DY. CHIEF FIRE OFFICE (NDZ)

DELHI FIRE SERVICE

To,

1. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053
2. The Chairman, Little Flowers International School located at C-11, 12 (100 feet Road), Kabir Nagar, Delhi-110094

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. Basement shall be used as per BBL.

1. Name & address of the building : Little Flowers International School
C-11, 12 (100 feet Road), Kabir Nagar, Delhi-94
2. Building is comprised of : B+G+2 (old bldg.) & G+3 (New bldg.)*
3. Type of Occupancy : Educational, Group-B
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/School/2022/NDZ/513 dt 12/05/2022
6. Fire Safety direction letter No. : NBC Part IV
7. Date of Inspection : 17/09/2025
8. Name of the Inspecting officers : ADO Deepak Kumar
9. Name and designation of Officer
from the building side : Sh. R. K. Dua (Chairman)
10. Year of Construction : 2006-2005 (old bldg.) & 2015 (new bldg.)
11. Applicant's letter No : LFIS/4778/2025 dated 13/08/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV/BBL Requirement	Provided at Site	Remarks MR/NMF
01	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m N/A N/A	15 m N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> Upper Floor 	02 nos. (old bldg.) 01 +01 EE (New bldg.)	03 nos. (old bldg.) 02 new bldg.)	MR
	<ul style="list-style-type: none"> Basement 	02 nos.	04 nos.	MR
	B. Width of Staircases			
	<ul style="list-style-type: none"> Upper Floor 	1.50 m + 1.50 m	1.01 m, 1.05m, 01 m (old bldg.) & 01 m & 1.52m new bldg.)	MR
	<ul style="list-style-type: none"> Basement 	1.50 m	1.01 m, 1.05m, 01m & 01m	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A N/A	N/A N/A N/A	N/A N/A N/A
	d. No. of continuous staircases to terrace			
		01 nos. in each block	01 nos. in each block	MR
	e. Width of Corridor	1.50 m	Provided	MR
	f. Door Size	01 m	01 m	MR
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
04	Smoke Management System.			
	<ul style="list-style-type: none"> Basement Upper floor 	12 ACPH N/A	Provided N/A	MR N/A


* The new building block consisting of G+3 floors is indicated at C-32 and N-14.



05.	Fire Extinguishers			
	• Total numbers	20 nos.	20 nos.	MR
	• Types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR
06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no +01 no.	Provided	MR
	• Length of hose reel hose	30 mtr	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access			
	• Terrace Level			
	➤ Discharge of pump	900 lpm	900 lpm + 450 lpm	MR
	➤ Head of the Pump	40 mtr	40 mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	15,000 ltr	15,000 ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2022/NDZ/842 dt 02/08/2022 **renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.**



 Signature of the Inspecting Officer
 Name :- Deepak Kumar
 Designation :- A.D.O (Shahdara)

~~DO(ED)~~ 
 By CFO (NDZ) 
 CFO.

Principal Director

Is banner allowed in schools?

By. CFO (NDZ)


 15/10/25

DO(ED)


 16/10/25


 16/10/25