



c/20

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F.6/DFS/MS/EH/SZ/2026/ 374

Dated: 20/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s Little Munchkins LLP, Located at Property No.-81, first floor, Adhchini Sri Aurobindo Marg, New Delhi-110016, in the building comprised of basement, ground plus 02 upper floors only. Owned/Occupied by M/s Little Munchkins LLT, was earlier issued Fire Safety Certificate by this department vide letter no F.6/DFS/MS/2023/SZ/EH/305 dated-12/10/2023. The premises was re-inspected by the officer concerned of this department on 07/04/2026 in the presence Sh. Ashok Kumar and found that the said premise have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premise is fit for occupancy class "Group-D" "Assembly Building" (for 1st floor only) and validity upto 31/03/2029 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 20/04/2026 at New Delhi by


(A.K. Malik)
Chief Fire Officer

Copy to:

1. The Commissioner MCD, Civic Centre, Minto Road, New Delhi- 110002. - to ensure the occupancy as detailed above & deviation if any
2. The authorized signatory, M/s Little Munchkins LLP, Located at Property No.-81, first floor, Adhchini Sri Aurobindo Marg, New Delhi-110016. (Online Portal ID No. -2026032303447 dated-23/03/2026.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to nonfunctional fire safety measure shall be at the responsibility of the management/occupier.
3. The trained firefighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.
9. This NOC/FSC is valid for first floor of the building only.

INSPECTION REPORT

INSPECTION REPORT				
1. Name & address of the building		M/s. Little Munchkins LLP, located at Property No.-81, first floor, Adhchini Sri Aurobindo Marg, New Delhi-110016.		
2. Type of Occupancy		Assembly Building. (video game parlor is running at first floor only), in a building comprised of basement + ground + 02 upper floors.		
3. Type of Case		Renewal		
4. Details of Previous NOC		F.6/DFS/MS/2023/SZ/EH/305 dated-12/10/2023		
5. Fire Safety directives letter No		Nill.		
6. Date of inspection		07/04/2026		
7. Name of Inspecting Officer		Sh. Sarabjeet Singh ADO (BCP)		
8. Name and designation of officers From the building side		Sh. Ashok Kumar		
9. Year of Construction		1998 (As per online application)		
10. Applicant's letter No.		Online-ID No -2026032303447 dated-23/03/2026		
S. No	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	09m	Provided	MR
	• Gate width	05m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02 Nos.	04 Nos.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floor	1.50m	2x1.50mtr, 1.25mtr & 1.0mtr	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Required	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.50mtr	1.50mtr, Provided	MR
3.	Compartmentation			
	a) Fire check door	NA	NA	NA
	b) Sealing of electrical shafts	NA	NA	NA
	c) Fire Rating of shaft door	NA	NA	NA
	d) Water Curtain	NA	NA	NA
	e) Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	a) Basements	NA	NA	NA
	b) Upper floors	Required	Exhaust fans provided	MR
5.	Fire Extinguishers			
	a) Total numbers	06 Nos.	06Nos. Provided	MR
	b) Types	ABC/CO ₂	ABC-04&CO ₂ -02	MR
	c) IS marking	ISI marked	Provided	MR

6.	First-Aid Hose Reels	01 Nos.	01 provided at first floor	MR
	a) Total numbers on each floor		Provided	MR
	b) Length of hose reel hose	30mm	Provided	MR
	c) Nozzle diameter	5m		
7.	Automatic fire detection and alarming system			NA
	a) Type of detectors	NA	NA	NA
	b) Location of Main Panel	NA	NA	NA
	c) Location of Repeater Panel	NA	NA	NA
	d) Alternate source of power	NA	NA	NA
	e) Hooters' Location	Required	Provided	MR
8.	MOEFA	NA	NA	NA
9.	Public Address System			
10.	Automatic Sprinkler System			NA
	a) Basement	NA	NA	NA
	b) Ground & Upper Floors	NA	NA	NA
	c) Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			MR
	a) Size of riser/down-comer	Required	Provided	MR
	b) Number of hydrants per floor	Required	Provided	MR
	c) Hose Box	Required	Provided	MR
12.	Yard Hydrants			NA
	a) Total number of hydrants	NA	NA	NA
	b) Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	Terrace level			
	➤ Discharge of pump	450LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for firefighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR

M/7

Provision of Lifts			
a)	Pressurization of Lift Shaft	NA	NA
b)	Pressurization of Lift lobby	NA	NA
c)	Communication In lift Car	NA	NA
d)	Fireman's Grounding Switch	NA	NA
e)	Lift Signage	NA	NA
17.	Standby power supply	NA	NA
18.	Refuge Area.		
	a) Total Area	NA	NA
	b) Location	NA	NA
19.	Fire Control Room		
	a) Detector System Panel	NA	NA
	b) Flow Switch Panel	NA	NA
	c) PA System Panel	NA	NA
	d) Battery backup	NA	NA
	e) Building Floor Plans	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F.6/DFS/MS/2023/SZ/EH/305 dated-12/10/2023, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signatures please.

Last Date of Disposal-20/04/2026


 10/4/2026
 Name- Sarabjeet Singh
 Designation - ADO(BCP)

DO (SD)


 13/4/24
 Ravinder Singh

CFI 18/4


 15/4/24
 A.K. MALIK
 Principal Director


 20/4/24
 A.K. MALIK


 17/04/24