



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/2026/School/WZ/ 60

Dated: 14/05/2026

FIRE SAFETY CERTIFICATE

Certified that the Little Star Model School located at T-1/8, Budh Vihar Phase-I, Delhi-110086. comprised of Ground & 02 Upper floor owned/ occupied by the Little Star Model School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 04/05/2026 in the presence of Sh. D.R. Gautam (Chairmen) and that the building/premises is fit for occupancy Class "Group B Educational (School)" with effect from14.05.2026. for a period of three years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on14.05.2026. at New Delhi

(S.K. Dua)
 (S.K. Dua)

Chief Fire Officer
 Delhi Fire Service

Copy to: -

1. The Dy. Director of Education, North-West, B-II, FU-Block, Pitampura, Delhi - 110034.
2. The Chairman, Little Star Model School at T-1/8, Budh Vihar Phase-I, Delhi-110086.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Little Star Model School at T-1/8, Budh Vihar Ph-I, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : New Case
4. Composition of building : Ground & 02 upper floor only
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : NBC Part-IV
7. Date of inspection : 04/05/2026
8. Name of the Inspecting Officers : ADO (Rohini)
9. Name and designation of officers from the building side : Sh. D.R. Gautam (Chairman)
10. Year of Construction : 2014 & 2018
11. Applicant's letter No. : Online e-mail dated 27/04/2026

	Minimum Standards on fire prevention and fire safety U/R 33	AS per previous inspection reports Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	06m	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.54m & 1.60m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	02	MR
	e. Width of Corridor	1.50m	Provided	MR
	f. Door Size	01m	Provided	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5	Fire Extinguishers.			
	• Total numbers	09nos	15 Nos.	MR
	• Types	ABC/Co2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	10,000 LTR	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/9

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:			

Note:- The observations/ shortcomings issued and communicated vide this department letter of even no. F6/DFS/MS/WZ/2020/125 dated 20/02/2020 have been complied by the management.


Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended for Grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name:- C.L. Meena
Designation:- Asst. Div. Officer (Rohini)

DO (NW) 
05/05/2026

CFO (WZ) 

Limp 
06/05/26

Pr. Director 

CFO to Jeeva


CFO (WZ) 


08/05/26
F.T. please.


Limp 
11/05/26

ADD (Rohini) 

As approved, F.T. letter is furup for your signature please

CFO (WZ) 

Limp 
13/05/26

F.P. wing 


12/05/2026