



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

624
THE FIRE SERVICE OF DELHI

No: F.6/DFS/MS/2025/WZ/ 731

Dated: 17/09/2025

To,

The Principal,
L.K. International School,
Auchandi Road, Bawana,
Delhi- 110039.

Sub: - Regarding renewal of Fire Safety Certificate in r/o L.K. International School located at Auchandi Road, Bawana, Delhi- 110039.

Sir,



This has reference to your letter No. LKIS/25-26/2108 dated 20/08/2025 received through outdoor diary no. 5056 dated 20/08/2025 on the subject cited above. In this connection, it is to inform you that the inspection of above said school building has been carried out by officer concerned of this department on 05.09.2025 to see the compliance of the existing fire safety measures. Sh. Ramesh Kumar was present at the time of inspection.

During the course of inspection it was observed that the school is running on Single Block (Basement, Ground plus Two upper floors) in a building comprised of Two Blocks (Basement, Ground plus Two upper floors & Ground plus first floor). Your request for renewal of FSC is rejected as the following shortcomings were observed:-

1. Smoke ventilation system found removed in basement
2. Sprinklers found removed in basement.
3. Ground level pump of 1000 lpm discharge capacity found removed.
4. Terrace level pump not found in auto mode.
5. Overhead tank of 5,000 ltrs capacity found provided against the required capacity of 15,000 ltrs.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for renewal of Fire Safety Certificate.

Yours Faithfully


16/09/2025
(Virendra Singh)
Chief Fire Officer


Copy to:-

1. Director of Education, Govt. Of NCT of Delhi, Old Secretariat, New Delhi.