

4181

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/NDZ/Hosp/2025/ 245

Dated 30/05/2025

To,
The Assistant Engineer (E), HC-2,
PWD, HMED (Central),
Lok Nayak Hospital, New Delhi.

Sub:- Regarding issuance of fire safety certificate to the various blocks of LNJP hospital, New Delhi.

Sir,

This has a reference to letter no. fire/AE(E)/HC-II/PWD/2025-26/13 dated 21.04.2025., on the subject cited above. In this regard, it is to inform you that the various block of LNJP hospital were inspected by the officer concerned of this department on 14.05.2025 in the presence of Sh. Manish Kumar AE (E) & JE (E), PWD and the following shortcoming were still not complied in three block

A. Causality OPD & surgical block.

1. 06 meter road for fire tender movement all around the said block is not provided Clearly.
2. One staircase of surgical block found blocked by dumping of waste items/materials, which may lead to obstacle/hurdle during evacuation of the occupants/patients of the surgical block at the time of emergency.
3. Hoses and branches found missing at some hydrant boxes.
4. Further, some floors of causality block are under renovation and fire fighting arrangements are disconnected.

B. Ortho Block:

1. 06 meter road all around the building for fire tender movement found Encroached with parking, shed and tree branches.
2. Detection system found non-functional.
3. MCP found non-functional.
4. Diesel engine is not in auto mode provision.
5. Hoses and branches found missing at some hydrant boxes
6. It was informed during inspection that ground and 7th floor are being renovated.

C. New Special Ward :

1. Lift Fire man switch found non functional.
2. Door closer found removed from some fire check doors.
3. Hoses and branches found missing at some hydrant boxes

In view of above shortcomings, the Fire Safety Certificate cannot be considered till compliance of above said shortcomings.

Yours Faithfully,

(Atul Garg)
DIRECTOR

Delhi Fire Service

Copy to:

1. The Medical Superintendent, LNJP hospital, New Delhi.
2. The Superintendent Engineer (SE), Electrical health & Maintenance, MSO building, Second floor, IP Estate, ITO, New Delhi.
3. The Executive Engineer (E)-II, Health Maintenance Electrical Division (Central), PWD NCTD, Lok Nayak Hospital, New Delhi.