



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

C/183
75-
11.11.2025

No.F6/DIS/MS/ND//2025/ 542

Dated 18/11/2025

To,

Dr. J. K. Basu,
MOIC PWD, Govt. of NCT of Delhi,
Lok Nayak Hospital, P.W.D. Branch,
New Delhi-110002.

Sub: Regarding renewal of Fire NOC for Various Blocks at Lok Nayak Hospital, New Delhi.

Sir,

This has reference to your letter No. F.No./Letter/PWD/LNH/2025/420 dated 26/09/2025, on the subject cited above. In this connection, it is to inform you that the premises (Surgical, Casualty, OPD & Ortho Blocks, Lok Nayak Hospital, New Delhi) was visited by the officers concerned of this department on 06/11/2025 and 10/11/2025 in the presence of Sh. Naresh Kumar, Asstt. Director (Planning), Sh. Manish Kumar Singh, A.E. (Electrical LNJP) and Sh. Surjeet Yadav J.E. (Civil) and following shortcomings were observed.

1. All around 06 mtr. wide motorable road with 09 mtr. turning radius for fire tender movement is not provided.
2. Lifts are not protected with lift lobby in basement.
3. Detectors are provided but found non-functional.
4. Pressurization system for lift shaft, lift lobbies and staircases not provided.
5. Automatic sprinkler system found not in working condition. Further, Sprinklers are not provided at some places including above false ceiling.
6. MOEFA provided but found non-functional.
7. Smoke management system provided but found non-functional.
8. Hose reel provided but found non-functional.
9. Fire check doors are not provided at some places.
10. Internal hydrant provided but found non-functional.
11. Shafts are not found sealed at some places.
12. H.T. & L.T. panels are not protected with Manual Operated CO₂ Flooding System.
13. Hoses are not provided in hose box at some places.
14. Panels provided in Fire Control Room are found non-functional.
15. Yard hydrant found damaged at some places.

In view of the above shortcomings, the application for issuance for Fire Safety Certificate is **rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Dr. S.K. Tomar)

Dy. Chief Fire Officer
Delhi Fire Service

o/c B

Copy to: -

1. Medical Superintendent, Lok Nayak Hospital, GNCTD, Jawahar Lal Nehru Marg, New Delhi - 110002
2. Deputy Secretary (Health), GNCTD, 9th Level, A-Wing, IP Extension, Delhi Secretariat, Delhi - 110002