



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/413

Dated: - 30/04/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi - 110001.

Sub: Regarding renewal of FSC in r/o M/s Lord Krishna Guest House, 2304-06, Laxmi Narayan Street, Chuna Mandi, Paharganj, New Delhi - 110055.

Sir,

This has reference to online application ID No. 2026040604436 dated 06/04/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officers concerned of this department on 22/04/2026 in presence of Mr. Javed, Manager to verify the compliance of shortcomings issued by this office vide letter No. F6/DFS/MS/GH/NDZ/2026/229 dated 19/03/2026 (copy enclosed) and found that the shortcomings as noted at Sr. No. 2 & 3 are not complied yet. Further, new construction was also ongoing at stilt level which is not in accordance with the plans submitted by the applicant.

In view of above, the application for renewal of fire safety certificate cannot be considered at this stage & stands **rejected**. Further, the occupancy of the premises in the absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

Encl.: As above


30/4/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to:

1. The Manager, M/s Lord Krishna Guest House, 2304-06, Laxmi Narayan Street, Chuna Mandi, Paharganj, New Delhi - 110055.

C-72 C-79

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/GH/NDZ/2026/229

Dated: - 19/03/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Lord Krishna Guest House, 2304-06, Laxmi Narayan Street, Chuna Mandi, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026021801759 dated 18/02/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officer concerned of this department on 10/03/2026 in the presence of Sh. Manish Gupta, Owner and following shortcomings were observed: -

1. Hose reel found removed in basement.
2. Internal hydrant found removed at some places.
3. Manually Operated Electronic Fire Alarm (MOEFA) found removed in basement.
4. Public address system provided but found non-functional.
5. Smoke management system provided in basement found non-functional.

Keeping in view of the above shortcomings, the application for renewal of Fire Safety Certificate cannot be considered at this stage and stands rejected. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


17/3/26

(Dr. S. K. Tomar)
Dy. Chief Fire Officer
Delhi Fire Service

o/c BR

Copy to: -

1. The Manager, M/s Lord Krishna Guest House, 2304-06, Laxmi Narayan Street, Chuna Mandi, Paharganj, New Delhi - 110055.