



C/64

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/GH/2025/SZ/ 189

Dated: 22/04/2025

To

The Joint Commissioner of Police (Lic.),  
1<sup>st</sup> Floor, P.S. Defense Colony  
New Delhi-110049

**Sub: Inspection report in r/o M/s Lotus International Guest House situated at Prop. No. 4390/21-24, Basant Road, Pahar Ganj, New Delhi-110055**

Sir,

This has reference to online (etl.mcdonline.nic.in) application Id. 2025033105015 dated 31/03/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department from fire safety point of view on dated 12/04/2025 in the presence of Sh. Rakesh Kumar Sidhu (Manager) of the guest house. During course of inspection, the shortcomings observed are as below.

1. First aid hose-reel found removed at 3<sup>rd</sup> floor.
2. Terrace level fire pump found non-functional.
3. Exit signage found removed at some locations.

In view of the above, the application for issuance of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

Ph. 011-23414000

Copy to: -

1. Authorized Signatory M/s Lotus International Guest House at Prop. No. 4390/21-24, Basant Road, Pahar Ganj, New Delhi-110055