



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



NO. F-6/DFS/MS/EH/2025/SZ/ 130

Dated: 20/03/2025

To

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor PS Defence Colony,
New Delhi 110049

Sub: - Regarding issuance of fire safety certificate in r/o M/s Loyal Hospitality Pvt. Ltd. at Plot No. 44, Block-A, Rajouri Garden, Delhi-110027.

Sir,

This has reference with **MCD Portal ID 2025022302297 dated 23.02.2025** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 06.03.2025 in the presence of Sh. Bhanu Gandhi, Owner to verify the present status of fire safety measures installed in the building. The fire safety arrangements were tested / checked and found following observations:-

1. Overhead tank capacity 20,000 liters not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. Mr. Junaiz Khizakkayil,
H. No. 23, Aristo 1, Sobha City,
Tanisandra Main Road, Hegde Nagar, Bengaluru,
Karnataka-560077