



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/17
7/5
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2025/ 462

Dated: 26/05/2025

To

The Principal,
Lucknow Public School,
L-1, Kh. No-57/13/2, Asthal Mandir Marg,
Sangam Vihar, New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of **Lucknow Public School** located at **L-1, Kh. No-57/13/2, Asthal Mandir Marg, Sangam Vihar, New Delhi.**

Sir,

With reference to the letter bearing outdoor diary no. 235 dated 04 .04.2025 on the subject cited above, it is informed that the said school was inspected by the officer concerned of this department on. 20.05.2025 in the presence of Mrs. Alka Mishra (Principal) and following shortcoming were observed at the time of inspection.

1. All water based systems like Hose Reels, Sprinklers System, Fire Pump found non functional.
2. Use of Basement is in violation to the undertaking dated 30.10.2018 submitted by the school management.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Garg)
Director
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.