



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

c/26

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2025/ 437

Dated: 22/05/2025

To

The Principal,
L.V.S. Public School
B-19, Sangam Vihar, New Delhi-62.

Sub:- Regarding renewal of Fire Safety Certificate in respect of **L.V.S. Public School** located at **B-19, Sangam Vihar, New Delhi-62.**

Sir,

With reference to the letter bearing outdoor diary no. 880 dated 22.04.2025 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 16.05.2025 in the presence of Mr. Satyaveer (Owner) and it was following shortcoming were observed.

1. Alternate staircases of 1.50 meters width from ground floor to terrace shall be provided.
2. 08 nos. of Fire Extinguishers shall be provided.
3. Hose reel shall be provided.
4. Fire pump having capacity 450 LPM & 40 m shall be provided.
5. Overhead fire tank 10,000 liters shall be provided.
6. Exit signages shall be provided.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.