



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No. F6/DFS/MS/School/WZ/2026/ 168

Dated:- 12/10/2026

FIRE SAFETY CERTIFICATE

Certified that the M Mothers Heart Play School located at Ground Floor, B- 138, Ganesh Nagar, New Delhi- 110018, play school is running at ground floor only in a building comprised of basement, ground plus three upper floors, owned/occupied by M Mothers Heart Play School have complied with the fire prevention and fire safety requirements in accordance with circular No. 3298-3398 dated 01/03/2011 issued by the Director of Education and verified by the officer concerned of Fire Service on 25/09/2026 in the presence of Sh. Dilbag Singh (Owner) and that the building/premises is fit for occupancy class "Educational Building" Group B (Play school at ground floor only) with effect from 12/10/2026 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on ...12/10/2026 at New Delhi by


12/10/26

A.K. Malik
Chief Fire Officer

Copy to: -

1. The Principal, M Mothers Heart Play School, Ground Floor, B- 138, Ganesh Nagar, New Delhi- 110018.

Conditions for validity of fire safety certificate: -

1. This FSC is valid for play school running at ground floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire-fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub-Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

4/3 INSPECTION REPORT

1. Name and address of the building : M Mothers Heart Play School located at
Ground Floor, B- 138, Ganesh Nagar, New
Delhi- 110018
2. Building comprised of : Basement + Ground + 03 upper floors
3. Type of Occupancy : Educational (Play School at ground floor only)
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives Letter No. : Nil
7. Date of inspection : 23/09/2026
8. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JKP)
9. Name and designation of Officer
from the building side : Sh. Dilbag Singh (Owner)
10. Year of Construction : 2000
11. Applicant's letter No. : Form 'I' dated 13/07/2026

The building is comprised of basement + ground + 03 upper floors but play school is running at ground only.

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Cr. No. 3298-3398 dated 01/03/2011	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.0 m	1.0 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA

5.	Fire Extinguishers			
	• Total numbers	03 nos.	03 nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access			
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump			
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA

N/5


18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked at the time of inspection.


Keeping in view of the substantial compliance of the minimum standards of fire prevention & fire safety measures required as per D.O.E circular 3298-3398 dated 01/03/2011 grant of Fire Safety Certificate is recommended.

Accordingly, DFA is prepared & put up for approval please.



Aman Kumar Lathar
ADO (JKP)

~~DO (SW)~~

20.9.26

~~DFO (W2)~~



05/10/2026
Debabrata Mukherjee

~~CFO (W2)~~



5/10/26
A.K. MALIK

~~H.O.~~ upto issue done 61x

~~CFO (W2)~~


8/10/26
A.K. MALIK

~~By CBO (W2)~~

ADO (JKP) F.T. letter is added for your signature to

A.K. MALIK
12/10/26