



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/SCHOOL/NDZ/2025/ 421

Dated: 21 /05/2025

To,

The Principal,
Maa Laxmi Public School
D – Block, Gokal Pur,
Delhi – 110094.

Subject: - Regarding Grant of Fire Safety Certificate in r/o Maa Laxmi Public School located at D – Block, Gokal Pur, Delhi – 110094.

Sir,

Please refer to your letter outdoor diary No. 1421 dated 07/05/2025 on the subject cited above. In this connection, it is to inform you that the site was visited by officer concerned of this department on 14/05/2025 in the presence of Principal and observed that the shortcoming has still not complied with as issued by this department vide letter no. F6/DFS/MS/School/NDZ/2025/192 dated 04/04/2025 (copy enclosed).

In view of above, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier.

Yours faithfully,

Enclosed: As above

Copy to: -

1. The Director of Education, B- Block, Yamuna Vihar, Delhi - 110053.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI ^{9/26}
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/NDZ/2025/ 192

Dated: 04/04/2025

To

The Principal,
Maa Laxmi Public School,
D-Block, East Gokulpur,
Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Maa Laxmi Public School located at D-Block, East Gokulpur, Delhi-110094.

Sir,

This has reference to your letter No. MLPS/2025/1 dated 20/01/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 28/03/2025 in the presence of Mrs. Renuka Prashant (Teacher) to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of **Ground Floor, 1st Floor, 2nd Floor & 3rd Floor**. However previous Fire Safety Certificate was issued to this premises vide letter No. F6/DFS/MS/School/2021/NDZ/685 dated 31/08/2021 for **Ground, 1st Floor & 2nd Floor only**. Following shortcomings were observed during the inspection:-

1. 02 Nos. Staircase of width 1.10mtr against requirement of two staircase of width 1.50mtr each.
2. Hose reel hose provided but found non-functional.
3. Fire Pump of capacity 450 LPM provided on terrace but found non-functional.
4. Overhead tank capacity of 1500 ltr is provided against requirement of 10,000ltr.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under :
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/Fire/Home_Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/Fire/Home/Forms

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.