GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI OF HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/NDZ/2025/ 192-

Dated: 04 /04/2025

To

The Principal, Maa Laxmi Public School, D-Bloack, East Gokalpur, Delhi-110094.

Sub: Regarding Fire Safety Certificate in r/o Maa Laxmi Public School located at D-Block, East Gokalpur, Delhi-110094.

Sir,

This has reference to your letter No. MLPS/2025/1 dated 20/01/2025 on the subject cited above. In this regard, it is to inform you that the premises was inspected by the officer concerned of this department on 28/03/2025 in the presence of Mrs. Renuka Prashant (Teacher) to ascertain the availability and operability of the fire prevention and fire safety measures and observed that at present building comprised of **Ground Floor**, 1st Floor, 2nd Floor & 3rd Floor. However previous Fire Safety Certificate was issued to this premises vide letter No. F6/DFS/MS/School/2021/NDZ/685 dated 31/08/2021 for **Ground**, 1st Floor & 2nd Floor only. Following shortcomings were observed during the inspection:-

- 1. 02 Nos. Staircase of width 1.10mtr against requirement of two staircase of width 1.50mtr each.
- 2. Hose reel hose provided but found non-functional.
- 3. Fire Pump of capacity 450 LPM provided on terrace but found non-functional.
- 4. Overhead tank capacity of 1500 ltr is provided against requirement of 10,000ltr.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected under sub rule (3) of Rule 37 of DFS Rules-2010. The occupancy of the building/premises in absence of requisite fire safety arrangement shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007 / Rules 2010 & Form "J" are as under: <a href="http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/Fire/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps wcm/connect/doit\_fire/Fire/Home/Forms">http://www.delhi.gov.in/wps wcm/connect/doit\_fire/Fire/Home/Forms</a>

Yours faithfully

ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.