

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ callege 118

Dated: 29/09/2025

To,

The Principal,

Madhav Shree Global School,

Plot No.7,8,9,42 & 43 Khasra No.2/17 & 2/24,

Rajeev Nagar Extn, Begumpur,

Delhi-110086.

Sub: Issue of FSC in r/o Madhav Shree Global School, Plot No.7,8,9,42 & 43 Khasra No.2/17 & 2/24, Rajeev Nagar Extn, Begumpur, Delhi-86.

Sir,

Kindly refer to your letter received in this department through Outdoor Diary No. 5387 dated 28.08.2025 on the subject cited above. In this connection, it is to inform you that the building of your institution (Ground + 02 upper floors) was inspected by this department, during which several shortcomings issued by this department vide letter no. 109 dated 10.09.2025 & letter no.52 dated 15.09.2025 were observed and already communicated to you earlier. Now, you have requested for issuance of Fire Safety Certificate only for the ground floor, where a school is being operated. In this regard, it is clarified that in previous occasion, Fire Safety Certificate is issued for the entire building as a whole and not partially for a single floor.

Therefore, you are directed to comply with the fire safety provisions for the entire building, rectify the shortcomings, and thereafter submit your application for issuance of Fire Safety NOC for the complete building.

> (Virendra Singh) Chief Fire Officer Delhi Fire Service

Copy to :-

1. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.



## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/2025/ Callege 109

Dated: 10 09 2025

To,

The Principal,

M. D. Indraprastha Institute for Higher Education,

Plot No.41-42, & 43 Khasra No.2/24,

Rajeev Nagar Extn, Begumpur,

Delhi-110086.

Sub: Issue of FSC in r/o M. D. Indraprastha Institute for Higher Education, Plot No.41-42, & 43 Khasra No.2/24, Rajcev Nagar Extn, Begumpur, Delhi-86.

Sir,

28.07.2025 on the subject cited above. In this connection it is to inform you that the building was visited by officer of this department on dated 26.08.2025 & it has been observed that the shortcoming already issued by this department letter of even No. 52 dated 15.09.2022 is not yet rectified (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings already issued vide this department letter dated 15.09.2022 for further consideration in this matter.

Yours Faithfully

(Virendra Singh) Chief Fire Officer Delhi Fire Service

> lle Nu-

Copy to:1. The Director of Education, GNCT of Delhi Old Secretariat, Delhi-110054.

## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001 No. F6/DFS/MS/WZ/2022/ 572 To.

The Principal,

M. D. Indraprastha Institute for Higher Education, Plot No.41-42, Khasra No.2/24, Rajeev Nagar, Begumpur Ext. Delhi-86.

Sub:Issue of FSC in r/o M. D. Indraprastha Institute for Higher Education, Plot No.41-42, Khasra No.2/24, Rajeev Nagar, Begumpur Ext. Delhi-86.
Sir,

Kindly reference to online e-mail dated 10.08.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 06.09.2022, in presence of Dr. Sarswati (Principal) to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

- 1. 03 fire extinguishers of ABC type provided against the required 06 no's of ABC / Co2 type 2.5 kg capacity required to be provided.
- 2. First Aid hose reel not provided.
- 3. Terrace Fire pump with capacity 450 LPM not provided.
- 4. 10,000 ltrs Over Head water captive tank not provided.
- 5. The required exit signage are not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under: <a href="http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Forms">http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Forms</a>

Yours faithfully

(Dhrampal Bhardwaj) Dy.Chief Fire Officer Tel;-01123414250