



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2025/ 39

Dated: 24/01/2025

To,

The Chief Architect,
DMRC Ltd. Metro Bhawan,
Fire Brigade Lane, Barakhamba Road,
New Delhi-110001

Sub:- Rejection of building plans from fire safety point of view in respect of Madhuban Chowk Metro Station, Pitampura, Delhi.

Sir,

With reference to online application ID no. DMRC/Fire/89/2024/09/388 dated 13.09.2024 on the subject cited above, it is informed that the referred online building plans in respect of Madhuban Chowk Metro Station, Pitampura, Delhi were scrutinized under rule 34 of The Delhi Fire Service Rules, 2010 and following shortcoming was observed:-

1. Continuous 6 meter wide road along with 9 meter turning radius for fire tender movement is not proposed as per National Building Code of India 2016/UBBL-2016.

In view of the above, the building plans are rejected with a request to resubmit plans after rectification of above shortcoming for further consideration.

Yours faithfully,

(Atul Garg)
Director

C M.S.