



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/CGHS/2025/SZ/ 388

Dated: 18/08/2025

To

Sh. C.M. Sharma (Member-MC),
Mahabhadra Kali CGHS Ltd,
Plot No. 06, Sector-13,
Dwarka, New Delhi-110078

Sub: Renewal of Fire Safety Certificate in r/o Mahabhadra Kali CGHS Ltd located at Plot No. 06, Sector-13, Dwarka, New Delhi-110078.

Sir,

This has reference to your letter No. Nil dated 12/06/2025 received in this department vide diary No. SW-259 dated 23/06/2025 on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 25/07/2025 in the presence of Sh. Harish Chandra Shukla (Manager). During course of inspection, **the shortcomings observed are as below:** -

1. Internal motorable road around the buildings found encroached/blocked.
2. First Aid Hose-reel & hydrant system found non-functional at some floors.
3. Terrace level fire pumps (High Rise Blocks) provided found non-functional.
4. Exit & lift signage's found removed at some locations.

In view of the above, **renewal of fire safety certificate is rejected**. You are advised to rectify the shortcomings mentioned above under intimation to this department. The residential complex remains unsafe from fire safety point of view and it shall be at the risk & liability of the management committee until the compliance.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Dy. Director (L&I), Building Section, Delhi Development Authority, Vikas Sadan, INA, New Delhi-110023