



No. F6/DFS/MS/BNQT/NDZ/2025/ 87

Dated: 19/05/2025

To,

The Joint Commissioner of police (Lic),  
1<sup>st</sup> Floor, Police Station, Defence Colony,  
New Delhi - 110024.

**Sub: - Regarding grant of Fire Safety Certificate in r/o M/s Mahadev Vatika located at Kh. No. 46/23 Kaushik Enclave, Revenue Esate Swaroop Nagar, Burari, Delhi - 110084.**

Sir,

This has a reference to your MHA Portal application No. 2025041406393 dated 14.04.2025 & 2025041406373 dated 14.04.2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officers concerned of this department on 03/05/2025 in the presence of Mr. Kunal & Mrs. Monika (Manager) and observed that building comprised of Ground + 02 upper floors, ground & first floor (Banquet Hall + Office), Second floor (Rooms).

**Following shortcomings were observed during time of inspection:**

1. Two staircases of width 1.20 meter & 0.95 meter are provided against requirement of 1.50 meters each. Both stairs should go to up to terrace floor.
2. Door size width of 1.50 meters provided against the requirement width of 2.0 meters.
3. First-Aid-Hose Reel is not provided.
4. MOEFA not provided.
5. Internal hydrant system not provided.
6. Fire pump of capacity 450 LPM not provided.
7. Overhead tank of 20,000 liters capacity not provided.
8. Exit & floors Signage's not provided in strategic location in the building.
9. Standby power supply not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate at this stage is rejected.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Manager, M/s Mahadev Vatika located at Kh. No. 46/23 Kaushik Enclave, Revenue Esate Swaroop Nagar, Burari, Delhi - 110084.