


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/School/WZ/2025/ 682

Dated: 22/08/2025

To,

The Principal,
 Maharaja Aggarsain Adarsh Public School,
 DU-Block, Pitampura, New Delhi-110088.

Sub: Regarding renewal of Fire safety certificate in R/o. Maharaja Aggarsain Adarsh Public School, DU-Block, Pitampura, New Delhi-110088.

Sir,

With reference to your Letter No. MAAPS/2025/3284 dated 21/07/2025, on the subject cited above. In this connection, it is to inform you that the said premises was inspected by the officer concerned of this department on 28/07/2025, in the presence of M/s. Neelu Goswami (Principal) to see the functioning of the fire safety arrangements/equipments provided in the building.

During inspection, it has been observed that the said school is running at ground and three upper floors, was already issued FSC vide letter No. F6/DFS/MS/School/WZ/2022/950 dated 05/09/2022. Fire safety arrangements such as, Fire Extinguishers, First Aid Hose Reels, Terrace pump etc, are provided. However, following shortcomings were observed: -

1. First Aid Hose Reels are provided but not functional.
2. Internal Hydrants are provided but not functional
3. Terrace fire pump of 450 LPM & 220 LPM are provided but not functional.
4. An Overhead water tank of 20,000ltrs is provided, but it is being used for domestic purposes.
5. Exit signage's are found removed at some places.

In view of above shortcomings, the application for **renewal Fire Safety Certificate is not consider at this stage & rejected**. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

21/8/2025
 Virendra Singh
 Chief Fire Officer
 21/8/2025

Copy To:-

1. The Director, Directorate of Education Old Secretariat Delhi – 110054.