

e/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/School/WZ/2025/277

Dated: 24/03/25

FIRE SAFETY CERTIFICATE

Certified that the **Maharaja Pyare Lal International, School, 1228, Street No.19, Shyam Colony, Budh Vihar, Phase-II, Delhi-86**, comprised of ground + 02 upper floors, but school running at **Ground + 01 upper floor only**, owned/ occupied by **Maharaja Pyare Lal International** have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education letter no 3298-3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on **27.02.2025** in the presence of **Mr. Harsh Kumar Garg** and that the building/ premise is fit for occupancy **Group B Educational (for ground + 01 floor only)** with effect from 24/03/25 for a period of **three years**, subject to compliance of the conditions mentioned below:

Issued on 24/03/25 at New Delhi by


(Atul Garg)
DIRECTOR
Ph: 011-23414000

Copy to:

1. The Principal, Maharaja Pyare Lal International, School, 1228, Street No.19, Shyam Colony, Budh Vihar, Phase-II, Delhi-86.
2. The Director of Education, Old Secretariat, Delhi

Conditions for validity of Fire Safety Certificate;

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form "K" is available on
[http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule s/](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rule+s/)
http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms

INSPECTION REPORT

1. Name & address of the building	Maharaja Pyare Lal International, School, 1228, Street No.19, Shyam Colony, Budh Vihar, Phase-II, Delhi-86.
2. Type of Occupancy	Educational
3. Comprised of building	Ground + 02 upper floors,
4. Type of Case	New Case (School running at ground + 01 upper floor only) 2 nd floor found under renovation & maintenance as given undertaking by school management
5. Details of Previous NOC	-NA-
6. Fire Safety directives letter No	Director of Education Cir. dated 01.03.2011.
7. Date of inspection	27.02.2025
8. Name of Inspecting Officer	Sh. Ajay Kumar Sharma (ADO Rohini)
9. Name and designation of officers From the building side	Mr. Harsh Kumar Garg
10. Year of Construction	2005
11. Applicant's letter No.	Online e-mail dated 21.02.2025.

S. No	Minimum Standards on fire prevention and fire safety U/R 33	DOE Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0mtr	Accessible	MR
	• Gate width	4.5m	Directly accessible	MR
	• Width of internal road	-NA-	-NA-	-NA-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01nos.	01nos.	MR
	• Basements	-NA-	-NA-	-NA-
	b. Width of staircases			
	• Upper Floor	1.5m	1.5m	MR
	• Basements	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircases to terrace	-NA-	-NA-	-NA-
	e. Width of Corridor	-NA-	-NA-	-NA-
	f. Door Size	-NA-	-NA-	-NA-
3.	Compartmentation	-NA-	-NA-	-NA-
	a) Fire check door	-NA-	-NA-	-NA-
	b) Sealing of electrical shafts	-NA-	-NA-	-NA-
	c) Fire Rating of shaft door	-NA-	-NA-	-NA-
	d) Water Curtain	-NA-	-NA-	-NA-
	e) Fire Dampers	-NA-	-NA-	-NA-
4.	Smoke Management System			
	a) Basements	-NA-	-NA-	-NA-
	b) Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	a) Total numbers	08nos.	08nos.	MR
	b) Types	ABC/CO2	ABC/CO2-10nos.	MR
	c) ISI marking	ISI marked	Yes	MR
6.	First-Aid Hose Reels			
	a) Total numbers on each floor	-NA-	-NA-	-NA-

	b) Length of hose reel hose	-NA-	-NA-	-NA-
	c) Nozzle diameter	-NA-	-NA-	-NA-
7.	Automatic fire detection and alarming system			
	a) Type of detectors	-NA-	-NA-	-NA-
	b) Location of Main Panel	-NA-	-NA-	-NA-
	c) Location of Repeater Panel	-NA-	-NA-	-NA-
	d) Alternate source of power	-NA-	-NA-	-NA-
	e) Hooters' Location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	a) Basement	-NA-	-NA-	-NA-
	b) Ground & Upper Floors	-NA-	-NA-	-NA-
	c) Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants			
	a) Size of riser/down-comer	-NA-	-NA-	-NA-
	b) Number of hydrants per floor	-NA-	-NA-	-NA-
	c) Hose Box	-NA-	-NA-	-NA-
12.	Yard Hydrants			
	a) Total number of hydrants	-NA-	-NA-	-NA-
	b) Hose Box	-NA-	-NA-	-NA-
13.	Pumping Arrangements			
	• Ground Level	-NA-	-NA-	-NA-
	➤ Discharge of main Pump	-NA-	-NA-	-NA-
	➤ Head of Main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump out put	-NA-	-NA-	-NA-
	➤ Jockey pump head	-NA-	-NA-	-NA-
	➤ Standby Pump out put	-NA-	-NA-	-NA-
	➤ Standby Pump Head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump House Access	-NA-	-NA-	-NA-
	Terrace level			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of the pump	-NA-	-NA-	-NA-
	➤ Power Supply	-NA-	-NA-	-NA-
	➤ Auto Starting of pump	-NA-	-NA-	-NA-
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire service inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead Tank capacity	-NA-	-NA-	-NA-
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	f) Pressurization of Lift Shaft	-NA-	-NA-	-NA-
	g) Pressurization of Lift lobby	-NA-	-NA-	-NA-
	h) Communication In lift Car	-NA-	-NA-	-NA-
	i) Fireman's Grounding Switch	-NA-	-NA-	-NA-

Day

17.	j) Lift Signage	-NA-	-NA-	-NA-
	Standby power supply	-NA-	-NA-	-NA-
18.	Refuge Area.			
	c) Total Area	-NA-	-NA-	-NA-
	d) Location	-NA-	-NA-	-NA-
19.	Fire Control Room			
	f) Detector System Panel	-NA-	-NA-	-NA-
	g) Flow Switch Panel	-NA-	-NA-	-NA-
	h) PA System Panel	-NA-	-NA-	-NA-
	i) Battery backup	-NA-	-NA-	-NA-
	j) Building Floor Plans	-NA-	-NA-	-NA-
20.	Special Fire Protection System for Protection of special Risks, if any:	-NA-	-NA-	-NA-

Accordingly, the fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education, and removal of shortcomings issued vide letter no. 883 dated 18.12.2024, under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
 Name Ajay Kumar Sharma
 Designation ADO(Rohini)

D.B Mukherjee
 DO (NW)

DCFO/1649-NW
 Dated 11/03/25

11/03/2025

Dy cfo (WZ)

11/3

CFO
 12/31/2025

Director
 13/03/25

for letter is put up
 for kind perusal and
 Signature Please.

Director