

FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE C-34

[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**


No.F.6/DFS/MS/School/2025/ 1071

Dated: 25/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Maharana Pratap Model Public School located at C-Block, Harsh Vihar, Delhi-110093 comprised of Ground plus One upper floor (A-Block) & Ground plus One upper floor (B-Block) (School is running on A-Block & Ground Floor of B-Block) owned / occupied by Maharana Pratap Model Public School was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/817 dated 06/10/2021. The school building was re-inspected by the officer concerned of this department on 08/08/2025 in presence of Mr. Kirti Kumar (Secretary) and observed that all the Fire Prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with circular letter No. F-16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education and observed that the **building / premises is fit for occupancy class "Educational" (Group-B)** with effect from 25/08/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 25/08/2025 at New Delhi by.

  
(VIRENDRA SINGH)  
CHIEF FIRE OFFICER.  
okA

Copy to :-

1. The Principal, Maharana Pratap Model Public School, C-Block, Harsh Vihar, Delhi-110093.
2. The Dy. Director of Education, B-Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc. shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)



# INSPECTION REPORT

1. Name & address of the building: Maharana Pratap Model Public School, C-Block, Harsh Vihar, Delhi-110093.
2. Type of Occupancy : Educational, Group-B (School)
3. Building Comprised of : A-Block (G+1) & B-block (G+1)  
(School is running on A-Block & ground floor of B-Block)
4. Type of Case : Renewal
5. Details of previous NOC No. F6/DFS/MS/School/2021/NDZ/817 dated 06/10/2021
6. Fire Safety directives Letter No. : DoE. Cir. No.3298-3398 dated 01/03/2011
7. Date of inspection : 08/08/2025
8. Name of the Inspecting Officer : A.K. Jaiswal (D.O.)
9. Name and designation of Officer from the building side : Mr. Kirti Kumar (Secretary)
10. Year of Construction : 2006
11. Applicant's letter No. : MPM/2025/338 dated 30/07/2025

S No	Minimum standards on fire prevention and fire safety	DOE Cir. dt. 1/3/11 Requirement	Provided at site	Remarks MR/NM
1.	Access of building			
	• Road width	06 m	06 m	MR
	• Gate width	NA	NA	NA
	• Width of internal	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 in each block	2 (A-Blk) & 1(B-Blk)	MR
	• Basements	NA	NA	NA
	Width of staircases			
	• Upper floors	1.50m	1.23m & 0.85m (Iron) A-Blk and 0.85m (B-Blk)	MR
	• Basements	NA	NA	NA
	Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	b. No of continuous staircase to terrace	1	1	MR
	c. Width Of Corridor	1.50 m	1.90 m	MR
	d. Door Size	01 m	01 m	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	8 Nos	8 Nos	MR
	• Types	ABC /Co2	Provided	MR
	• ISI marking	ISI Marked	Provided	MR

M/18				
6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA



15.	Exit Signage	NA	NA	NA
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2021/NDZ/817 dated 06/10/2021 **renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.**

*Ashok Kumar Jaiswal*  
12/08/2025  
Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal  
Designation: D.O. (East)

Dy. C.F.O. (NDZ)

C.F.O.

16/8/2025

Principal Director

DO (East)

*CF to Secy.*

*22/08/2025*

*22/8/2025*

p.f.o.