

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2025/School/WZ/ 1034

Dated 20/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Maharishi Dayanand Public School located at Ishwar Colony Bawana, Delhi-110039 comprised of Ground + First floor & one servant room at terrace was issued FSC by this department vide letter No F6/DFS/MS/2019/WZ/2244 dated 29.11.2019. The premises was re-inspected by the officer concerned of this department on 26.07.2025 in the presence of Smt. Sarita Rani (Principal), and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from ... 20.08.25... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on 20 08 2025. at New Delhi by

(Virendra Singh) Chief Fire Officer

Copy to:-

1. The Director, Education, Government of NCT of Delhi. Old Sect. Delhi-110054

The Principal, Maharishi Dayanand Public School located at Ishwar Colony Bawana, Delhi-110039.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.

2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.

3. The trained fire fighting staff should be available round the clock.

4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.

5. This certificate cannot be treated in any case for regularizations of unauthorized construction.

6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

N-8 1. Name & address of the building: Maharishi Dayanand Public School located at Ishwar Colony, Bawana, 2. Type of Occupancy Delhi- 110039. 3. Building Comprised of Educational 4. Type of Case Ground plus first floor & 01 Servant Room at terrace 5. Details of Previous NOC Renewal 6. Fire Safety directives letter No F6/DFS/MS/2019/WZ/2244 dated 29/11/2019 7. Date of inspection DOE circular No. 3298-3398 dated 01/03/2011 8. Name of Inspecting Officer 26/07/2025 9. Name and designation of officers R.K.Sinha, ADO (BW) From the building side 10. Year of Construction Smt. Sarita Rani (Principal) 11. Applicant's letter No. Since 2005 Outdoor Diary No. 3594 dated 10/07/2025 Minimum Standards on fire DOE Requirement/ prevention and fire safety U/R 33 Provided at site No. Remarks Inspection report MR/NMR dated 06/11/2019 1. Access to building Road width 6 m Provided MR Gate width 4.5 m Directly Accessible MR Width of internal road NA NA NA Number, Width, Type & Arrangement of Exits a. Number of staircases Upper Floors 01 02 MR Basements NA NA NA b. Width of staircases Upper Floor 1.50 m 1.30 m & 1.05 m MR (old case) Basements NA NA NA c. Protection of exits Fire check door NA NA NΛ Pressurization NA NA NA d. No. of continuous staircases to NA NA terrace NA e. Width of Corridor NA NA NA

2. 1 m f. Door Size Provided MR 3. Compartmentation Fire check door NA NA NA NA Sealing of electrical shafts NA NA Fire Rating of shaft door NA NA NA Water Curtain NA NA NA Fire Dampers NA NA NA 4. Smoke Management System Basements NA NA NA Upper floors Required Naturally Ventilated MR Fire Extinguishers 5. Total numbers 3 Nos. Provided MR Types ABC/ CO2 Type Provided MR IS marking Required Provided MR First-Aid Hose Reels 6. Total numbers on each floor NA NA NA Length of hose reel hose NA NA NA Nozzle diameter NA NA NA Automatic fire detection and alarming system Type of detectors NA NA NA Location of Main Panel NA NA NA Location of Repeater Panel NA NA NA Alternate source of power NA NA NA

NE

	• Hoote-1:	4.6		100
8.	MOEFA Hooters' Location	NA		_
).	Public Address System	NA	NA	NA NA
10.		NA NA	NA	NA NA
u.	Automatic Sprinkler System	NA.	NA	NA NA
				1.44
	Dasement	N/A		
	Glound Floor	NA NA	NA	NA
1.	Sprinkler above follow	NA NA	NA	NA NA
	Internal Hydrants	NA	NA	NA NA
	• Size of rice (1			
	Size of riser/down-comer Number of budgets	NA		
	Number of hydrants per floor Hose Box	NA	NA	NA
12,	Yard Hydrants	NA	NA NA	NA
_			NA	NA
	Total number of hydrants	N		
13.	Hose Box	NA	NA	1
	Pumping Arrangements	NA	NA	NA NA
100	Ground Level			INA
	➤ Discharge of main Pump			
	> II	NA	NA	
	> Head of Main pump	NA	NA NA	NA
	Number of main pumps	NA		NA
	Jockey Pump out put	NA NA	NA	NA
	Jockey pump head	NA NA	NA	NA NA
	Standby Pump out put	NA NA	NA	NA NA
	Standby Pump Head	NA NA	NA	NA NA
	Auto Starting/Manual	NA NA	NA	NA
	Stopping		NA	NA
	> Pump House Access	NA	NA	NA
	Terrace level		F	
	Discharge of pump			
		NA NA	NA	NA
	➤ Head of the pump	NA	NA	NA NA
	> Power Supply	NA	NIA	A STAN
4.	> Auto Starting of pump	NA	NA NA	. NA
**	Captive Water Storage for fire fighting		IVA	NA
	Underground tank capacity	NA	NA	
	Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA NA	NA
	➢ Access to tank	NA	NA NA	NA
	Overhead Tank capacity	NA	NA NA	NA
5.	Exit Signage.	NA	NA NA	NA NA
6.	Provision of Lifts.		AMA.	NA
	• December of contract	15.		
	Pressurization of Lift Shaft	NA	NA	. NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
7.	Standby power supply	NA	NA	NA
8.	Refuge Area.			1
		NA	NA	NA
	➤ Total Area	NA	IVA	IVA

	Fire Control Room				
+	Detector System Panel	NA	NA	NA	
-	Flow Switch Panel	NA	NA	NA	
1		NA	NA	NA	
	PA System Panel		NA	NA	
	Battery backup	NA	NA	NA	
	Building Floor Plans	NA	W. MACHE	NA	
	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	1.7.	

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: Electric meter and electrical panel are not under the staircase.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular no. 3298-3398 dated 01/03/2011, it is recommended to renew the Fire Safety Certificate issued vide letter number F6/DFS/MS/2019/WZ/2244 dated 29/11/2019.

> Signature of Inspecting Officer Name: Rajeev Kumar Sinha Designation: ADO/B.W.

DCF0/289-NW Dated 04/08/25

Jochw) 04/08/202