

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2025/ School/ 1018

Dated: 19/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the **Maharshi Dayanand Public School** located at 2580, Arya Samaj Mandir, Shadipur Khampur, Mandir Wali, opp. West Patel Nagar, New Delhi-110008, comprises of Ground + 03 Upper floor, was earlier granted FSC by this department vide letter No. **F6/DFS/MS/School/SZ/2021/706 Dated 03.09.2021**. Now, the premises was re-inspected by the officer concerned of this department on 31/07/25 in the presence of the **Mrs. Neerja Mahendiratta Principal** and found that said school premises has deemed complied with the fire prevention and fire safety requirements in accordance **Director of Education circular dated 17.01.2005** and the **premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I** with effect from **19.08.2025** for a period of **three years** subject to compliance of the conditions mentioned below:

Issued on **19/08/2025** at New Delhi by.

  
 (Virendra Singh)  
 Chief Fire Officer  
 Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, Maharshi Dayanand Public School located at 2580, Arya Samaj Mandir, Shadipur Khampur, Mandir Wali, opp. West Patel Nagar, New Delhi-110008.

**Conditions for the validity of fire safety certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. Any flammable material for interior decoration shall strictly prohibited.



**INSPECTION REPORT**

1. Name & address of the building:- Maharishi Dayanand Public School, 2580, Arya Samaj Mandir, Shadipur, Khampur, New Delhi.
2. Type of occupancy:- Educational Group B-I, Gr.+03 Upper Floor
3. Type of case:- Renewal
4. Details of previous NOC:- F6/DFS/MS/School/SZ/2021/706 dated 03/09/21.
5. Fire safety directives No.- Director of education circular 17.01.2005
6. Date of inspection:- 31/07/25.
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- **Mrs Neeraj Mahendiratta , Principal**
9. Year of construction:- Before 2007.
10. Applicant's letter No:- letter no. 203/MDPS/Session-2025-26 dated 09.07.2025

Old Case ( renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per previous FSC	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	4.5 mtr.	4.5 mtr.	MR
	2) Gate width	4.5 mtr.	Provided	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.25 mtr	1.25, 1.05 mtr. each	MR being old case
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	02	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.0 mtr.	0.98mtr	MR being old case
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural vent	MR
5.	Fire Extinguishers			
	1) Total numbers	6 Nos.	Provided	MR
	2) Types	ABC & CO2	Provided	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number	01	Provided	MR



	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	Provided	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	Provided (100mm)	N/A
	2) Number of hydrants per floor	N/A	Provided (01 no.)	N/A
	3) Hose box	N/A	Provided (01no.)	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	Provided	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Underground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	5,000 ltr.	Provided	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of lift	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	Required	O2 ABC type fire extinguishers are provided near elect. pannel	MR

The fire protection system provided in school building were tested, checked at random and found functional at the time of inspection

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter No. F6/DFS/MS/School/SZ/2021/706 dated 03/09/21, under rule 35(6) of the Delhi Fire Service Rules 2010. Accordingly, FSC is recommended for approval and DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name: - Sh. Ravinder Singh  
Designation: ADO (CC)

Dn/cb

5/8/25

CFO

11/8/2025

Principal Director

CFO to Secy.

CFO

13/8/25

ADO(CC) As approved for put up for renewal signed by car

CFO

13/8/2025

MS

18/8/25