



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/GH/NDZ/2026/ 494

Dated: 21/05/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
Civic Centre, Minto Road,
New Delhi

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Mahesh Dx., Plot No. 121, Krishan Gali, Ghee Mandi, Paharganj, New Delhi - 110055.

Sir,

Please refer your online application ID No. 2026042005424 dated 20/04/2026 on the subject cited above. In this connection, it is to inform you that the said building was inspected by the officers concerned of this department on 05/05/2026 in the presence of Sh. Kausar Alam, Manager and following shortcomings were observed: -

1. Alternate staircase and exit of 1.50 mtr. wide was not provided in the building.
2. Exit signage and Lift signage was not provided in the building.
3. Smoke management system was not provided in the building.
4. Domestic connection found provided in Overhead tank which is not permitted.

Further, basement is not mentioned in the building plans enclosed with the application form.

Keeping in view of the above shortcomings, the application for issuance of Fire Safety Certificate cannot be considered at this stage and stands **rejected**. Further, the occupancy of the building premises in the absence of requisite fire safety measures shall be at the risk and liability of the owner/occupier.

Yours Faithfully,


21/5/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Manager, M/s Mahesh Dx., Plot No. 121, Krishan Gali, Ghee Mandi, Paharganj, New Delhi - 110055.