

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/Business/2025/SZ/236

Dated: 09/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Main Court Building** at **Distt. Court Complex, Saket New Delhi 110017** comprised of 02 Basement, Ground plus Seven Upper Floors, was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Business/2022/SZ/168 dated 13/04/2022. The premise was inspected by officer concerned of this department on 05/05/2025 in the presence of Mr. Rishikesh Pathak JE-(E) Court and found that the building/premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class **Group-E, Business Occupancy** with effect from the 09/05/2025 for period of **Three Years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued 09/05/2025 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Executive Engineer (E) PWD Sub Div. M-4223, PWD, at Distt. Court Complex, Saket New Delhi 110017
2. The Hon'ble District Judge (South) District Court Complex, Saket, New Delhi 110017

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. The basement shall be used as per the provisions of BBL-/NBC Part- IV.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL- 2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

INSPECTION REPORT

1. Name & address of the building : Main Court Building, Saket Court Complex, New Delhi
2. Type of Occupancy : Business "Group-E"
3. Type of Case : Renewal
4. Comprised of : (Court Building)-2B+G+7
5. Details of Previous FSC : F6/DFS/MS/Business/2022/SZ/168 dated 13/04/2022
6. Fire Safety directives letter No : F6/DFS/MS/BP/2004/2448 dated 14/10/2004 & F6/DFS/MS/BP/2006/1119 dated 15/05/2006
7. Date of inspection : 05/05/2025
8. Name of Inspecting Officer : Sh. Rajesh Kumar ADO (BCP)
9. Name and designation of officer from the building side : Mr. Rishikesh Pathak JE-(E) Court
10. Year of Construction : 2010
11. Applicant's letter No. : F.(23)AE(E)/Sub/Div/03/Judiciary E/Div-1/PWD/205 dated 17/04/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	9m 5m 6m	Provided Provided Provided	MR MR MR
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors 	Court Building - 18 Nos + One Ramp	Court Building 16 Nos up to 7 th F, 18 Nos up to 5 th F & 20 Nos up to 4 th F+ One Ramp at all levels up to terrace [Lower Basement to 7 th F terrace: 09 Nos., Lower Basement to 7 th F: 4 Nos, G.F. to 7 th F: 3 Nos, Lower Basement to 5 th F terrace: 1 Nos, G. F. to 4 th F: 2 Nos]	MR in Nos (old case)
	<ul style="list-style-type: none"> Basements 	Court Building -30 Nos	Court Building - Lower Basement to Upper Floors: 13 Nos, Lower Basement to GF: 12 Nos	MR in Nos (old case)
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	Court Building 13 of 1.2m, 2 of 1.35m, 1 of 1.5m & 2 of 2m	Court Building - 16 Nos up to 7 th F, 18 Nos up to 5 th F & 20 Nos up to 4 th F+ One Ramp at all levels up to terrace [Lower Basement to 7 th F terrace: 2.1m, 1.4m, 1.49m, 1.33m, 1.34m, 1.34m, 2m, 1.26m & 1.2m Lower Basement to 7 th F: 1.16m, 1.16m, 1.2m, 1.18m G.F. to 7 th F: 1.22m, 1.23m, 1.22m Lower Basement to 5 th F terrace: 1.4m, G. F. to 4 th F: 1.43m, 1.44m + Ramp of 1.5m	MR (old case)

	<ul style="list-style-type: none"> Basements 	Court Building - 21 of 1.25m, 5 of 1.35m, 2 of 1.5m & 2 of 2m	Court Building - Lower Basement to Upper Floors: 1.51m, 1.38m, 1.26m, 1. 22m, 1.38m, 1.98m, 1.96 m, 1.24m, 1.18m, 1.26m, 1.37m, 1.49m, 1.34m Lower Basement to GF: 1.23m, 1.2m, 1.22m, 1.2 2m, 1.24m, 1.23m, 1.24 m, 1.23m, 1.18m, 1.25m, 1.24m, 1.27m
	c. Protection of exits	Required	Provided
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required	Provided
	d. No. of continuous staircases to terrace	Required	9Nos on 7 th F terrace & 1 Nos on 5 th F terrace,
	e. Width of Corridor	1.5m	Provided
	f. Door Size	1m	Provided
3.	Compartmentation		
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required	Provided
		Required	Provided
		NA	NA
		NA	NA
		Required	Provided
4.	Smoke Management System		
	<ul style="list-style-type: none"> Basements Upper floors 	30 ACPH 12 ACPH	Provided Provided
5.	Fire Extinguishers		
	<ul style="list-style-type: none"> Total numbers Types IS marking 	300No's ABC/W. CO ₂ /CO ₂ ISI marked	310 150/140/20 Provided
6.	First-Aid Hose Reels		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	6 th & 7 th F-9 Nos GF to 5 th F-10 Nos Basement-13 Nos 30m 5mm	Provided Provided Provided
7.	Automatic fire detection and alarming system		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat Ground Floor NA Required Every Floor	Provided Provided NA Provided Provided
8.	MOEFA	Required	Provided
9.	Public Address System	Required	Provided
10.	Automatic Sprinkler System		
	<ul style="list-style-type: none"> Basement Upper Floors Sprinkler above false ceiling 	Required Required Required	Provided Provided Provided

M6

Internal Hydrants				
	Size of riser/down-comer	100mm	Provided	MR
	Number of hydrants per floor	6 th & 7 th F-9 Nos	Provided	MR
	Hose Box	GF to 5 th F-10 Nos Basement-13 Nos	Provided	MR
12. Yard Hydrants				
	Total number of hydrants	Required	20 No's	MR
	Hose Box	Required	20 No's	MR
13. Pumping Arrangements				
	Ground Level			
	➤ Discharge of main Pump	2850 LPM	Provided	MR
	➤ Head of Main pump	70m	Provided	MR
	➤ Number of main pumps	Two	Provided	MR
	➤ Jockey Pump out put	2 x 300 LPM	Provided	MR
	➤ Jockey pump head	70m	Provided	MR
	➤ Standby Pump out put	2850 LPM	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/Manual Stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14. Captive Water Storage for fire fighting				
	Underground tank capacity	2,00,000 Lts	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	Overhead Tank capacity	20,000 Lts	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16. Provision of Lifts.				
	Pressurization of Lift Shaft	Required	Provided	MR
	Pressurization of Lift lobby	Required	Provided	MR
	Communication In lift Car	Required	Provided	MR
	Fireman's Grounding Switch	Required	Provided	MR
	Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18. Refuge Area.				
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19. Fire Control Room				
	Detector System Panel	Required	Provided	MR
	Flow Switch Panel	Required	Provided	MR
	PA System Panel	Required	Provided	MR
	Batter backup	Required	Provided	MR
	Building Floor Plans	Required	Provided	MR

20.	Special Fire Protection System for Protection of special Risks, if any:	Required	Clean Agent flooding is provided in HT & LT Panel (Utility Building)	MA
-----	---	----------	--	----

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/Business/2022/SZ/168 dated 13/04/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

[Signature]
6/5

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

DO (SD) *[Signature]*
[Signature]
7/5/2025

[Signature]
[Signature]

As approved, F.T. letter is put up for your signature #1

[Signature]
[Signature]

[Signature]
9/5