

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2025/SZ/1069

Dated: 17 / 06 / 2025

To

Sh. Satesh Kumar,
ASO (Fire Safety),
Administrative Block,
AIIMS, New Delhi-110029

Sub: Renewal of Fire Safety Certificate in r/o Main Hospital Building (Ward Block, OPD and Old Private Ward), AIIMS Complex, Ansari Nagar, New Delhi-110029

Sir,

This has reference to the email received from Id: satesh@aiims.gov.in dated 22/05/2025, on the subject cited above. In this connection, the said premise was re-visited by the officer concerned of this department on dated 11/06/2025 in the presence of Sh. B.S. Yadav (Dy. CSO) to see the compliance of shortcomings issued vide this office letter No. F.6/DFS/MS/Hospital/2024/SZ/192 dated 25/04/2025 and observed that the left-over shortcoming has not been complied as yet.

In view of the above, the renewal of fire safety certificate cannot be considered at this stage. You are requested to complete the repair/renovation work under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000

01/06/25



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2024/SZ/ 192

Dated: 25/04/2025

To

Sh. Salesh Kumar,
ASO (Fire Safety),
Administrative Block,
AIIMS, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Main Hospital Building (Ward Block, OPD and Old Private Ward), AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This is with reference to the email received from Id: salesh@aiims.gov.in dated 05/03/2025, on the subject cited above. In this connection, the said premise was visited by the officer concerned of this department on dated 09/04/2025 in the presence of Sh. Harinder Singh (Dy. CSO) to see the compliance of shortcomings communicated vide this office letter No. F.6/DFS/MS/SZ/2024/74 dated 23/02/2024 and the status of shortcomings observed is as below.

S. No.	Shortcomings issued	Present Status
1.	Automatic fire detector found removed in lift room at terrace.	Complied
2.	Exit signage at 8 th floor found removed.	Complied
3.	Lift No. 11 & 17 found under repair/renovation	Complied
4.	The opening of exit door at terrace floor shall be outwards.	Complied
5.	Some part of 2 nd Floor found under repair/renovation.	Not Complied
6.	Electric panel found installed in escape route at 9 th floor.	Complied

In view of the above, the application for renewal of fire safety certificate cannot be considered at this stage. You are requested to complete the repair/renovation work under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL GARG)
DIRECTOR

Ph. 011-23414000