



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/Hospital/2025/SZ/ 1614

Dated: 10/09/2025

To

Colonel Digvijay Singh,
Chief Security Officer,
Administrative Block,
AIIMS, New Delhi-110029



Sub: Renewal of Fire Safety Certificate in r/o Main Hospital (Ward Block, OPD & Old Private Block, AIIMS, New Delhi-110029)

Sir,

This has a reference to your letter No. Nil dated 05/08/2025 received in this department vide outdoor diary No. 4761 dated 12/08/2025, on the subject cited above. In this connection, it is informed that the said premise was visited by the officer concerned of this department on 20/08/2025 in the presence of Sh. Manoj Kumar (AEE) & Sh. Sailesh Kumar, ASO (Fire Safety) to verify the compliance of shortcomings issued vide this office letter No. F.6/DFS/MS/Hospital/2025/SZ/192 dated 25/04/2025. During course of inspection, addition/alteration was observed as the hospital management has erected a canteen made of steel/iron frame and operational at the terrace floor without approval/intimation to this department.

In view of the above, renewal of fire safety certificate cannot be considered at this stage until the receipt of approved/sanction drawing of the canteen and date of operation of canteen etc. for further action in the matter.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service


Copy to: -

1. The Executive Engineer (C)-III, All India Institute of Medical Science, Ansari Nagar, New Delhi-110029



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2025/SZ/ 192

Dated: 25/04/2025

To

Sh. Satesh Kumar,
ASO (Fire Safety),
Administrative Block,
AIIMS, New Delhi-110029

Sub: **Renewal of Fire Safety Certificate in r/o Main Hospital Building (Ward Block, OPD and Old Private Ward), AIIMS Complex, Ansari Nagar, New Delhi-110029**

Sir,

This is with reference to the email received from Id: satesh@aiims.gov.in dated 05/03/2025, on the subject cited above. In this connection, the said premise was visited by the officer concerned of this department on dated 09/04/2025 in the presence of Sh. Harinder Singh (Dy. CSO) to see the compliance of shortcomings communicated vide this office letter No. F.6/DFS/MS/SZ/2024/74 dated 23/02/2024 and the status of shortcomings observed is as below.

S. No.	Shortcomings issued	Present Status
1.	Automatic fire detector found removed in lift room at terrace.	Complied
2.	Exit signage at 8 th floor found removed.	Complied
3.	Lift No. 11 & 17 found under repair/renovation	Complied
4.	The opening of exit door at terrace floor shall be outwards.	Complied
5.	Some part of 2 nd Floor found under repair/renovation.	Not Complied
6.	Electric panel found installed in escape route at 9 th floor.	Complied

In view of the above, the application for renewal of fire safety certificate cannot be considered at this stage. You are requested to complete the repair/renovation work under intimation to this department for further action in the matter.

Yours faithfully,

(ATUL KARG)
DIRECTOR
Ph. 011-23414000