



FIRE SAFETY CERTIFICATE

Certified that the **Majeedia Model School located at C - 41/5, Jama Masjid Marg, North Ghonda, Delhi - 110053**, now comprised of Ground + 02 upper floors only (Earlier it was Ground + 01 upper floor only for which Fire Safety Certificate was issued by this department vide letter No. F6/MS/DFS/2006/2896 dated 28/09/2006. The premises have complied with fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of fire service on 08/05/2025 in the presence of Mr. Ansab Riyaz (Principal) and that the premises is fit for the occupancy class (Group - B) **"Educational Building" for ground plus two upper floor only** with effect from 21/05/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 21/05/2025 at New Delhi by.


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, MCD Civic Centre, Jawahar Lal Nehru Marg, New Delhi.
2. The Principal, Majeedia Model School located at C - 41/5, Jama Masjid Marg, North Ghonda, Delhi - 110053.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Majeedia Model School located at C - 41/5, Jama Masjid Marg, North Ghonda, Delhi - 110053.		
2	Building is comprised of	Ground plus two upper floors		
3	Type of occupancy	Educational Building		
4	Type of case	New Case (Addition/Alteration)		
5	Details of previous FSC	F6/MS/DFS/2006/2896 dated 28/09/2006 for ground + 1 upper floor		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	09/05/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Ansab Riyaz (Principal)		
10	Year of construction	2001		
11	Applicant's letter no.	Email dated 15/04/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part-IV Requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	6.0 meters.	6.0 meters	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	01 no.	02 nos.	MR ✓
	b Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 meters.	1.50 meters & 1.20 meters.	MR ✓
	b Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no.	01 no.	MR
	E Width of corridor	1.50 meters.	1.06 meters.	MR Old Accepted
	F Door size	1.0 meter.	1.0 meter.	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A

W


A

Majeedia Model School located at C - 41/5, Jama Masjid Marg, Noida				
5.	Fire Extinguisher:			
	A	Total numbers	06 nos.	06 nos. MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC MR
	C	ISI marking	ISI Marked	ISI Marked MR
6	First-Aid-Hose Reel:			
	A	Total numbers of each floor	01 no.	01 no. MR
	B	Length of hose reel hose	30 mtrs.	30 mtrs. MR
	C	Nozzle diameter	05 mm	05 mm MR
7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	N/A	N/A N/A
	B	Location of main panel	N/A	N/A N/A
	C	Location of repeater panel	N/A	N/A N/A
	D	Alternate source of power	N/A	N/A N/A
	E	Hooters	N/A	N/A N/A
8	MOEFA:		N/A	N/A N/A
9	Public Address System:		N/A	N/A N/A
10	Automatic Sprinkler System:			
	A	Basement	N/A	N/A N/A
	B	Upper floor	N/A	N/A N/A
	C	Sprinkler above false ceiling	N/A	N/A N/A
11	Internal Hydrants:			
	A	Size of riser/down-comer	N/A	N/A N/A
	B	Number of hydrants per floor	N/A	N/A N/A
	C	Hose box	N/A	N/A N/A
12	Yard Hydrants:			
	A	Total number of hydrants	N/A	N/A N/A
	B	Hose box	N/A	N/A N/A
13	Pumping Arrangements:			
1	Ground level			
	A	Discharge of main pump	N/A	N/A N/A
	B	Head of main pump	N/A	N/A N/A
	C	Number of main pumps	N/A	N/A N/A
	D	Jockey pump out put	N/A	N/A N/A
	E	Jockey pump head	N/A	N/A N/A
	F	Standby pump out put	N/A	N/A N/A
	G	Standby pump head	N/A	N/A N/A
	H	Auto starting /manual stopping	N/A	N/A N/A
	I	Pump house access	N/A	N/A N/A
2	Terrace Level			
	A	Discharge of pump	450 LPM	450 LPM MR
	B	Head of the pump	40 mtrs.	40 mtrs. MR
	C	Power supply	Required	Provided MR
	D	Auto starting of pump	Required	Provided MR

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters.	10,000 liters	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:		N/A	N/A	N/A
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/School/2015/700 dated 10/04/2015 has been rectified.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/2006/2896 dated 28/09/2006 for ground + 1 upper floor, renewal under Rule 35 (6) of the Delhi Fire Service rules 2010, is recommended.



10/5/2025

Signature of the Inspecting Officer
Name : Yashwant Singh Meena
Designation: ADO /Laxmi Nagar

D.O/EAST


10/05/2025

By C.F.O. (N.S.Z.) 
13/05/25

C.F.O. 
12/5/2025


16/5/25

