



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001




No.F6/DFS/MS/2025/Metro/ 404

Dated 04/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Majlis Park Metro Station, DMRC Delhi comprised of Ground i.e Concourse & Platform Level owned/ occupied by Delhi Metro Rail Corporation Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 23/07/2025 in the presence of Sh. Ajay Bhati (Manager/DMRC) & Team and that the building/ premise is fit for occupancy class "Group D Assembly Building (Metro Station)" with effect from 04/08/2025 for a period of three year, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/08/2025 at New Delhi by


Virendra Singh
Chief Fire Officer
Delhi Fire Service


Copy to:-

1. Sh. Shailendra Kumar (AGM/E&M/RC-1), Delhi Metro Rail Corporation Ltd at First floor, Haiderpur Badli Mor Metro Station, Shalimar Bagh, New Delhi-110088.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape shall be kept free from any type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
3. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
5. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
6. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Majlis Park Metro Station, DMRC
2. Type of Occupancy : Assembly (Metro)
3. Composition of building : Basement (only for pump room), Ground i.e Concourse & Platform Level
4. Type of Case : New
5. Details of previous NOC : Nil
6. Fire Safety directives letter No : F6/DFS/MS/BP/2021/416 dated 20.09.2021
7. Date of inspection : 23/07/2025
8. Name of the Inspecting Officers : DO (NW) & ADO (RN)
9. Name and designation of officers from the building side : Sh. Ajay Bhati (Manager/DMRC) & Team
10. Year of Construction : --
11. Applicant's letter No. : DMRC/Elect/PH4/RC-1/DE01/Lot1/Fire NOC/530/4751 dated 07/07/2024

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV/ UBBL-2016 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	14m	Provided	MR
	• Gate width	4.50m	Provided	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03 nos. of Ground i.e concourse level to platform level	Provided	MR
	• Basements	01	Provided	MR
	b. Width of staircases			
	• Upper Floors	3.80m	Provided	MR
	• Basements	1.20m	Provided (only for pump room)	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	02m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural ventilation	MR
5	Fire Extinguishers			
	• Total numbers	20nos.	Provided	MR
	• Types	ABC, CO2 & Foam type	Provided	MR
	• ISI marking	Required	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	03nos	03nos of ground level & 03 nos. of platform level	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Ground level	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Every floor	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100mm	03nos of ground level & 03 nos. of platform level	MR
	• Number of hydrants per floor	03	Provided	MR
	• Hose Box	03	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	01	Provided	MR
	• Hose Box	01	Provided	MR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2850 LPM	Provided	MR
	➤ Head of Main pump	70m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put			
	➤ Jockey pump head	180 LPM	Provided	MR
	➤ Standby Pump out put	2850 LPM	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,00000 LTR	Provided	MR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts. Passenger lift is provision but not in working order & locked by DMRC			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

M/10

MR
MR
NA
MR
MR
MR
MR
MF

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	ABC Type fire extinguisher & Co2 flooding system near HT/ LT Panel	MR

The fire protection systems provided in the building were tested/ checked and found functional at the time of inspection.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures required under the rules, it is recommended to issue Fire Safety Certificate.

Signature of the inspection Officer
Name :- D.B. Mukharjee
Designation:- DO/NWD

Signature of the Inspecting Officer
Name :- C.L. Meena
Designation:- ADO/RN

DCFO/274-NW
Dated 28/07/25

Dy cfo (NW)

25/7/2025

CFO
29/7/2025

Principal Director

CFO to Ins.

20/7/25

ADO (RN)

As approved, F.T. letter is put up for your signature please.

CFO
28/8/2025

MS cell / FFW

31/07/2025