



No. F6/DFS/MS/School/NDZ/2025/ 798

Dated: 18/06/2025

FIRE SAFETY CERTIFICATE

Certified that Mamta Public School at Vasundhara Enclave, Shaheed Budh Ram Singh Marg, (Near Vasundhara Bhawan), Delhi - 110096, building comprised of ground plus one upper floor only owned/occupied by Mamta Public School was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/2022/NDZ/School/804 dated 28/07/2022. The school building was re-inspected by the officer concerned of this department on 09/06/2025 in presence of Mr. Gyanendra Singh (Security Guard) of the school and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and observed that the building is fit for occupancy class "Educational Building" (Group - B) with effect from 18/06/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010. Subject to conditions, printed below.

Issued on 18/06/2025 at New Delhi by.

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Director of Education, Old Secretariat, Delhi - 110054.
2. The Principal, Mamta Public School at Vasundhara Enclave, Shaheed Budh Ram Singh Marg, (Near Vasundhara Bhawan), Delhi - 110096.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	Mamta Public School at Vasundhara Enclave, Shaheed Budh Ram Singh Marg, (Near Vasundhara Bhawan), Delhi-110096.			
2	Building is comprised of	Ground & One Upper Floor only			
3	Type of occupancy	Educational Building			
4	Type of case	Renewal			
5	Details of previous FSC	F6/DFS/MS/2022/NDZ/School/804 dated 28/07/2022			
6	Fire safety directives letter no.	Circular No. 262 - 362 dated 17/01/2005			
7	Date of inspection	09/06/2025			
8	Name of the inspecting officers	Yashwant Singh Meena ADO (Laxmi Nagar)			
9	Name of the designation of officer from the building side	Mr. Gyanendra Singh (Security Guard)			
10	Year of construction	2004			
11	Applicant's letter no.	Outdoor Diary No.2140 dated 27/05/2025			
S. No	Minimum standard of fire prevention and fire safety U/R 33	Circular Requirement	Provided at site	Remarks MR/NMR	
1.	Access to Building:				
	A	Road width	6.0 mtrs.	15 mtrs.	MR
	B	Gate width	4.5 mtrs.	4.5 mtrs.	MR
	C	Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:				
	A	Number of staircases			
	a	Upper floor	01 no.	01 nos.	MR
	b	Basement	N/A	N/A	N/A
	B	Width of staircases			
	a	Upper floor	1.50 mtrs.	1.50 mtrs.	MR
	b	Basement	N/A	N/A	N/A
	C	Protection of exits			
	a	Fire check door	N/A	N/A	N/A
	b	Pressurization	N/A	N/A	N/A
	D	No. of continuous staircases to terrace	01 no.	01 no.	MR
	E	Width of corridor	1.50 mtrs.	1.50 mtrs. & 1.20 mtr.	MR
	F	Door size	1.0 mtr.	1.0 mtr.	MR
3.	Compartmentation:				
	A	Fire check door	NA	NA	NA
	B	Sealing of electrical shafts	N/A	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	N/A	N/A
4.	Smoke Management System:				
	A	Basement	N/A	N/A	N/A
	B	Upper floor	N/A	N/A	N/A

5. Fire Extinguisher:				
A	Total numbers	04 nos.	04 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	Required	Provided	MR
9	Public Address System:	N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

(3)

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	5000 liters	Provided
15	Exit Signage:		N/A	N/A
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:		N/A	N/A
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:		N/A	N/A

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards on fire prevention and fire safety measures as required under the Rules the Fire Safety Certificate issued vide letter no. F6/DFS/MS/2022/NDZ/School/804 dated 28/07/2022 under the Circular No. 262 - 362 dated 17/01/2005 is recommended.


10/6/2025

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

DO/ED

by ADO (NDZ)

C.F.O

Director

12/6/2025

13/6/25

LVP
11/06/25

Not in

Q.S.D