



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F6/DFS/MS/WZ/2026/139

Dated: 23.04.2026

To,

The Medical Superintendent,
Manav Sevarth Trust Hospital,
Action Cancer Hospital,
A-4, Paschim Vihar, New Delhi-110063.

Sub: - Inspection report in r/o M/s Manav Sevarth Trust Hospital (Action Cancer Hospital) located at FC-34, A-4 Block, Paschim Vihar, New Delhi - 110063.

Sir,

As per directions of the Competent Authority vide office order no. F6/DFS/HQ/2026/494 dated 20/03/2026, it is submitted you that the surprise inspection of above said Hospital building has been carried out by the officer concerned on 13.04.2026 to see the compliance of the requisite fire safety measures. Sh. Sunder Singh was present at the time of inspection.

Following shortcomings were observed at the time of inspection:-

1. Internal road of 6 m width found obstructed due to new construction.
2. There are only 03 no. of staircases and one ramp in Block A against the requirement of 04 staircases and one ramp.
3. Door closer of fire check doors found removed at some places.
4. Overhead tank of 6000 ltrs water storage capacity found provided against the requirement of 20000 ltrs capacity.
5. Exit signages found removed at some places.
6. Store room inside the ramp and pantry inside the staircase are not permitted.

You are advised to rectify the above-mentioned shortcoming under intimation to this department, till than the occupancy of the Building/ Premise in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/ Occupier.

Yours Faithfully

S.K. Dua
Chief Fire Officer
Delhi Fire Service